




STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. Q1252-H

**HVAC WORK
REMOVE FUEL OIL TANKS
BUILDING No's. 133, 142
AND WOODED AREA
HUDSON PSYCHIATRIC CENTER
10 ROSS CIRCLE
POUGHKEEPSIE, NY**

November 25, 2008

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

ADDENDUM NO. 2 TO PROJECT NOS. 43039-C,E

**CONSTRUCTION WORK, ELECTRICAL WORK
PROVIDE PLAYGROUND AND PAVILIONS
NYS SCHOOL FOR THE BLIND
2A RICHMOND AVENUE
BATAVIA, NEW YORK**

November 25, 2008

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**ADDENDUM NO. 2 TO PROJECT NO. 43162-C
ADDENDUM NO. 1 TO PROJECT NOS. 43162-H,P
ADDENDUM NO. 4 TO PROJECT NO. 43162-E**

**CONSTRUCTION WORK, HVAC WORK,
PLUMBING WORK, ELECTRICAL WORK
PROVIDE CHILLER CONNECTIONS
OFT DATA & NETWORK CENTER**

**40 NORTH PEARL STREET
ALBANY, NY**

November 25, 2008

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

ADDENDUM NO. 1H

November 25, 2008

ADDENDUM NO. 2C,E

November 25, 2008

ADDENDUM NO. 2C, 1H,P, & 4E

November 25, 2008

CHANGES TO ADDENDUM NO. 1

1. Item No. 5: Change "Limestone" to "Granite".
2. Delete Item No. 7 in its entirety.

CD FILE ERROR

3. The Contract Document CD (Disk 1 of 1) contains a misfiled drawing under the Contract Drawings folder. Drawing 43608-C_010_H-101.TIF was inadvertently filed in the 02-HVAC folder and should have been filed in the 01-Construction folder.
4. CERTIFICATION PAGE (000105): Change "EXECUTIVE DEPARTMENT – OFFICE OF GENERAL SERVICES" to "EXECUTIVE DEPARTMENT – OFFICE OF CHILDREN AND FAMILY SERVICES".
5. Page 000110 – 1: Change "015000 Temporary Controls" to "015000 Construction Facilities & Temporary Controls".
6. DOCUMENT 001114 ADVERTISEMENT FOR BIDS: The last date for receipt of bids is changed from Wednesday, November 26, 2008, to Wednesday, December 3, 2008.

7. DOCUMENT 003126 EXISTING HAZARDOUS MATERIAL INFORMATION: Add the accompanying document (pages 003126 – 1 thru 003126 – 7) to the Project Manual.
8. DOCUMENT 004102 BID FORM: Discard the Bid Form bound in Project Manual and use the accompanying Bid Form noted “Revised 11/25/2008”.
9. Page 007307 – 3, Subparagraph 26.2 (a): Change “6%” to “7%”.

SPECIFICATION GROUP

10. Page 011000 – 3, Add the Following Article to PART 1 GENERAL:
“1.10 RESTRICTED WORK PERIOD
 - A. Do not perform Work requiring shut off of active heating piping and equipment between October 15th and May 1st unless approved otherwise, in writing, by the Director.
 1. The above period will not be included in the number of days specified for completion of the Work.”
11. SECTION 034816 PRECAST CONCRETE SPLASH COURSE: Add the accompanying section (pages 034816 – 1 and 034816 – 2) to the Project Manual.
12. Page 323113 – 3, Article 2.06, Add the Following Paragraph:
“M. Corrosion-Inhibiting Admixture: ASTM C 494/C 494M - 04, for use in resisting corrosion of steel reinforcement.”
13. 221426 ROOF DRAINS: Discard the Section bound in the Project Manual and substitute the accompanying Sections (pages 221426 – 1 thru 221426 – 4) noted “Revised 11/25/2008”.
14. 265300 EXIT LIGHT FIXTURES: Discard all previously issued versions and substitute the accompanying Section (pages 265300 – 1 thru 265300 – 3) noted “Revised 11/25/2008”.

15. Page 323113 – 2, Article 2.04: Delete this Article in its entirety.
16. Page 221100 – 1, Paragraph 2.01 C.: Delete this paragraph in its entirety.
17. Page 099101 – 8, Change Paragraph 2.03 C. to Read:
 - “C. Colors: Provide paint colors to be selected by the Director from finish paint manufacturers available color selections.
 1. Approved finish paint manufacturers to match designated colors of other manufacturers where colors are shown on contract documents.”
18. Page 260501 – 3, Subparagraph 2.01 G. 4. a.: Add “electroplate” after “zinc” in the first line.
19. CCA-1 NEW YORK STATE UNIFORM CONTRACTING QUESTIONNAIRE: Discard the Questionnaire bound in the Project Manual and use the accompanying Questionnaire dated 11/25/2008.
20. CONTRACTOR’S CERTIFICATION STATEMENT: Add the accompanying Document (pages 1 of 2 and 2 of 2) to the Project Manual.

DRAWINGS

21. Drawing No. M-101:
 - a. NOTES Column, Change Note 1. to Read:
 - “1. Provide 3 hour fire rated damper.”
22. Drawing No. E-601:
 - a. FLOOR PLAN: Add 5 computer outlets to LAB 106. Locate outlets centered 3 feet above finished floor, at locations directed.
23. Addendum Drawing:
 - a. Drawing No. M-102, noted “ADDENDUM DRAWING 11/25/2008” accompanies this Addendum and forms part of the Contract Documents.

CONSTRUCTION WORK DRAWINGS

24. Drawing No. A-103:
- a. FLOOR PLAN, Rooms 5 and 6: Remove approximately 150 sq. ft. of existing concrete floor slab and floor finishes to allow the work of related contracts to be performed. Coordinate exact removal requirements with related contracts through the Director's Representative. When directed, after related contract work is completed, replace concrete floor slab and floor finishes to match existing. See Detail 2/A-103.
 - b. SECTION 1/A-103: Change "BRICK" to "CONCRETE".
25. Revised Drawings:
- a. Drawing Nos. A-301 and A-502, noted "REVISED DRAWING 11/25/2008" accompany this Addendum and supersede the same numbered originally issued drawings.

PLUMBING WORK DRAWINGS

26. Drawing No. P-501:
- a. Floor Plan: Change "4 inch House Trap" to "6 inch House Trap".
27. Revised Drawing:
- a. Drawing No. P-101, noted "REVISED DRAWING 11/25/2008" accompanies this Addendum and supersedes the same numbered originally issued drawings.
28. Addendum Drawing:
- a. Drawing No. P-102 accompanies this Addendum and forms part of the Contract Documents.

CANCELATION

29. This Project is canceled. Discard Bidding and Contract Documents.
30. The bidding of this Project is canceled. Discard Bidding and Contract Documents.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction

SAMPLES