



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



**ADDENDUM NO. 2 TO PROJECT NO. 42673
REHABILITATE ELECTRICAL DISTRIBUTION SYSTEM
COXSACKIE CORRECTIONAL FACILITY
11260 ROUTE 9W, BOX 200
WEST COXSACKIE, NY**

May 4, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATION GROUP

1. Page 017329-1, Revise paragraph 1.03 B to read as follows:

“B. Existing Paint: Assume existing painted surfaces to contain lead based paints. Take precautions as required to prevent spread of lead containing particles and dust. Refer to Section 028304- HANDLING OF LEAD CONTAINING MATERIALS. “
2. Page 235415-2, Article 2.01: Revise paragraph D as follows:

“D. Provide a manually operated on-off-auto switch for single speed units. Provide automatic controller for operation with 120V thermostat. Provide disconnect switch for 120V control circuit at unit.”
3. Page 261219-1, Paragraph 1.02 C, Add the following subparagraph:

“3. Data indicating compliance with NEMA Class 1 Energy Efficiency Level. “
4. Page 261219-4, Paragraph 2.01 A, Add the following subparagraph:

“10. Nema Class 1 Energy Efficiency Level. “
5. Document 261319 MODIFICATIONS TO METAL CLAD SWITCHGEAR: Delete this section in its entirety.

ELECTRICAL WORK DRAWINGS

6. Drawing No. 201A:
 - a. Revise manhole designation of PMH-5 to PMH-6 and PMH-6 to PMH-5.
 - b. For Portable Generator Quick Connect Switchboard, include reference to Drawing E-203.
 - c. For underground conduit note, delete "GRC" description.
 - d. For high voltage switches and transformers HV-3, HV-3A, TR-3, & TR-3A, revise their location arrangement to HV-3, TR-3, HV-3A & TR-3A referencing from north to south.

7. Drawing No. E-202:
 - a. Delete manhole PMH-5 and revise manhole PMH-6 to PMH-5.

8. Drawing No. E-236:
 - a. Detail 1A: For Fire Alarm System IAM tie in, reference Detail1 on Drawing E-001.

9. Drawing No. E-237:
 - a. Detail 1/237: At IAM fire alarm system module, indicate reference to Detail 1/E-001 One Line Diagram on Drawing E-001

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction