



**ADDENDUM NO. 1 TO PROJECT NO. 43003
PLUMBING WORK AND ELECTRICAL WORK
REPLACE FIRE PUMPS AND REPAIR HOUSE TANKS
EMPIRE STATE PLAZA
ALBANY, NY 12242**

December 11, 2012

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

PROJECT AND ADDENDUM CLARIFICATION

1. The Contract Drawings were originally produced as separate contracts for Construction (C), Hazardous Materials (B), Plumbing (P), Fire Protection (N) and Electrical (E). The Construction Work, Plumbing Work, Hazardous Material Work and Fire Protection Work are combined into a single all inclusive Plumbing Work Contract (P). There is also an Electrical Work Contract (E).

DRAWINGS

2. Drawing Nos. S-101, S-102, S-201, S-202. and S-501, DRAWING TITLE BLOCK:
 - a. Change "Construction" contract designation to read "Plumbing".
 - b. Change "43003-C" project number to read "43003-P".
 - c. Change drawing title to read "Replace Fire Pumps and Repair House Tanks".
3. Drawing No. S-101, SCOPE OF WORK, Note S: Add the following to the end of this Note: "Provide access holes as directed".
4. Drawing No. H-101, DRAWING TITLE BLOCK:
 - a. Change "Hazardous Materials" contract designation to read "Plumbing".
 - b. Change "43003-B" project number to read "43003-P".
5. Drawing Nos. P-101 and P-102, KEYED NOTES:
 - a. Change "C - Contract" to read "P - Contract".
 - b. Change "N - Contract" to read "P - Contract".
6. Drawing No. P-101, NOTES: Add the following Note:

"14. Repair any disturbance to existing fireproofing to match existing."
7. Drawing No. P-102, NOTES:
 - a. Note 9: Delete this note in its entirety and replace with the following:

"9. Repair any disturbance to existing fireproofing to match existing."
 - b. Note 10: Delete this Note in its entirety.

ADDENDUM NO. 1 TO PROJECT NO. 43003-P & E

8. Drawing Nos. E-001, E-101, E-102, E-103, E-104, E-105, and E-106:
 - a. Change “N Contract” to read “P Contract”.
 - b. Change “Construction Contract” to read “Plumbing Contract”.
 - c. Change “B Contract” to read “P Contract”.
 - d. Change “N Contractor” to read “P Contractor”.
9. Drawing No. E-001, SYMBOLS, ABBREVIATIONS, & ONE LINE DIAGRAMS: Change “Electrical Allowance” to read “Related Work for Electrical Allowance”.
10. Drawing Nos. FA-001, FA-101, and FA-102: Change “Fire Protection Drawings” to read “Plumbing Drawings”.
11. Drawing Nos. F-001, F-101, F-102, F-103, F-104, F-105, F-106, F-107, F-108, F-109, F-110, F-111, F-112, F-501, F-502, F-503, F-504, F-505, F-601, and F-602; DRAWING TITLE BLOCK:
 - a. Change “Fire Protection” contract designation to read “Plumbing”.
 - b. Change “43003-N” project number to read “43003-P”.
12. Drawing Nos. F-001, F-101, F-102, F-103, F-104, F-105, F-106, F-107, F-108, F-109, F-110, F-111, F-112, F-501, F-502, F-503, F-504, F-505, F-601, and F-602:
 - a. Change “B - Contract” to read “P - Contract”.
 - b. Change “N - Contract” to read “P - Contract”.
13. Drawing No. F-001, FIRE PUMP NOTES:
 - a. Note 18: Change “175psi” to read “300 psi”.
 - b. Add the following Note:
“29. Repair any disturbance to existing fireproofing to match existing.”
14. Drawing No. F-501, DETAIL 5: Add the following Note:
“Extend 1/2 inch pressure sensing line for jockey pump to nearest floor drain. Assume 40 linear feet.”

END OF ADDENDUM

James Dirolf, P.E.
Director of Design