




STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



**ADDENDUM NO. 1 TO PROJECT NO. 43091
CONSTRUCTION WORK
REPLACE WINDOWS AND DOORS
BUILDING No. 12
WALLKILL CORRECTIONAL FACILITY
P.O. BOX G ROUTE 208
WALLKILL, NY 12589-0286**

January 20, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. Section 085123, 1.05 Submittals, D. Quality Control Submittals.
 - a. Replace paragraph 2 with the following:
 2. Each type of window shall be removed and opening evaluated by the Director's Representative before final shop drawing submittal. Location of removal shall be determined by Directors Representative.

DRAWINGS

1. Drawing No. A-508
 - a. Revise all dimension strings to indicate a '+/-' after the dimension, i.e. x'-xx" +/-
 - b. At window schedule, change quantity for type 2 window to 174.
 - c. At window schedule, change quantity for type 5 window to 81

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction