



ADDENDUM NO. 3 TO PROJECT NO. 43153

**CONSTRUCTION WORK, MECHANICAL WORK,
PLUMBING WORK, ELECTRICAL WORK
PROVIDE VISITOR CENTER BUILDING AND SITE IMPROVEMENTS
FIVE RIVERS ENVIRONMENTAL EDUCATION CENTER
56 GAME FARM ROAD
DELMAR, NY 12054**

June 26, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK DRAWINGS [Contract: 43153-C]

1. Sheet A-101, Floor Plan General Note 4
 - a. To the greatest extent possible all contractors shall avoid concealing devices that require access above inaccessible architectural ceilings. Each contractor shall:
 - Endeavor to locate accessible devices over support areas with no or accessible ceilings
 - Provide a shop drawing indicating all devices that require access above inaccessible ceilings of significant architectural spaces
 - Identify all items requiring access on coordination drawings and coordinate location to minimize number of access panels required.
 - b. C-Contractor shall figure that 30 access doors will be required

ELECTRICAL WORK DRAWINGS [Contract: 43153-E]

1. Sheet E-400
 - a. Delete panel feeder to tire barn from one-line diagram.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction