



ADDENDUM NO. 2 TO PROJECT NO. 43248

**FIRE PROTECTION WORK
SPRINKLER SYSTEM RENOVATIONS
BUILDING 41
ROCHESTER PSYCHIATRIC CENTER
1111 ELMWOOD AVENUE
ROCHESTER, NY**

February 20, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

DRAWINGS

1. Drawing FA-101:
SHEET NOTES, ADD Notes 6, 7, 8 and 9:
 6. Fire alarm work shown or detailed Drawing FA-101 is provided by others with the exception of the installation of water flow devices and tamper switches.
 7. Contractor shall furnish and install water flow devices (a.k.a. water-flow indicators) and tamper switches (a.k.a. valve supervisory switches) per Specification Section 211313, 2.06 and in strict accordance with the manufacturer's instructions.
 8. Wiring, conduit, connection to the FACU and programming for the water flow devices and tamper switches to be by provided by others.
 9. Contractor shall coordinate with the separate fire alarm contract in accordance with Article 17 of the General Conditions.

2. Drawing FA-102:
SHEET NOTES, ADD Notes 5, 6, 7 and 8:
 5. Fire alarm work shown or detailed on Drawing FA-102 is provided by others with the exception of the installation of water flow devices and tamper switches.
 6. Contractor shall furnish and install water flow devices (a.k.a. water-flow indicators) and tamper switches (a.k.a. valve supervisory switches) per Specification Section 211313, 2.06 and in strict accordance with the manufacturer's instructions.
 7. Wiring, conduit, connection to the FACU and programming for the water flow devices and tamper switches to be by provided by others.
 8. Contractor shall coordinate with the separate fire alarm contract in accordance with Article 17 of the General Conditions.

ADDENDUM NO. 2 TO PROJECT NO. 43248-N

SPECIFICATIONS

1. Specification 283105:
 - 1.02 PROJECT SCOPE, ADD Paragraph L:
 - L. All fire alarm requirements in this specification are provided by others.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design