



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 5 TO PROJECT NO. 43704  
CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK & ELECTRICAL WORK  
REHABILITATE FOOD SERVICE  
OPERATIONS, BUILDING NOS. 3 & 20  
WENDE CORRECTIONAL FACILITY  
3040 WENDE ROAD  
ALDEN, NY**

June 15, 2012

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.  
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**SPECIFICATIONS**

Specification Section 221100 - Plumbing Piping:

Refer to Page 221100-9, Article 3.08.G. Add the following Item 2:

- "2. Exposed Piping Serving Food Service Equipment, Except Piping Installed Within Cabinets, And Not Exposed To View: Polished, chrome plated grade A brass pipe with cast brass fittings, and threaded joints."

**DRAWINGS**

Drawing M-103 - Phase-1 Bldg-20, 1<sup>st</sup> Floor Mechanical:

Refer to attached Sketch SKM-2 for revised Steam Equipment Connection Schedule.

Drawing M-107 - Phase-2 Bldg-3, Mechanical:

Refer to attached Sketch SKM-3 for revised Steam Equipment Connection Schedule.

Drawing M-601 - Schedules - Mechanical:

Refer to attached Sketch SKM-1 for revised Pressure Reducing Valve Schedule.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design



**STEAM EQUIPMENT CONNECTION SCHEDULE**

SERVICE	ACTUAL CAPACITY LBS/HR	MPS CONNN SIZE	MPC CONN SIZE	TRAP SIZE	RELIEF VALVE DISCHARGE CONN SIZE
60 GAL KETTLE "L" - TEMP KITCHEN	193	3/4"	1/2"	3/4"	2"
60 GAL KETTLE "L" - TEMP KITCHEN	193	3/4"	1/2"	3/4"	2"
60 GAL KETTLE "M" - TEMP KITCHEN	193	3/4"	1/2"	3/4"	2"
STEAMER - TEMP KITCHEN	138	1/2"	1/2"	3/4"	-

ADDENDUM

REFERENCE DRAWING: M-103

SHEET TITLE:

PHASE-1 BLDG-20, 1ST FLOOR MECHANICAL

PROJECT: REHABILITATE FOOD SERVICE OPERATIONS  
BUILDING NOS. 3 & 20

WARNING: THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.

DWG NO:  
SKM-2



NYS OFFICE OF GENERAL SERVICES

Serving New York

CONTRACT: HVAC

PROJ. NO: 43704-H

DATE: 06/14/12

DRAWN: ARL

APPROVED:



KIDNEY ARCHITECTS

200 John James Audubon Parkway

Buffalo, New York 14228

716-636-9700 . Fax: 716-636-9783

KIDNEY ARCHITECTS PC

ARCHITECTS, PLANNERS

INTERIOR & LANDSCAPE DESIGN

EA PROJECT: 2008056.00



ENGINEERING P.C.

MECHANICAL/ELECTRICAL

ENGINEERING CONSULTANTS

WATERFRONT VILLAGE CENTER

SUITE 300, 60 LAKEFRONT BOULEVARD

BUFFALO, NY 14203

(716)845-5002 FAX: (716)845-0187

M/E JOB 08159

**STEAM EQUIPMENT CONNECTION SCHEDULE**

SERVICE	ACTUAL CAPACITY LBS/HR	MPS CONN. SIZE	MPC CONN. SIZE	TRAP SIZE	RELIEF VALVE DISCHARGE CONN. SIZE
80 GAL KETTLE *24	210	1-1/4"	1/2"	3/4"	2"
60 GAL KETTLE *25	193	3/4"	1/2"	3/4"	2"
60 GAL KETTLE *25	193	3/4"	1/2"	3/4"	2"
60 GAL KETTLE *25	193	3/4"	1/2"	3/4"	2"
40 GAL KETTLE *26	124	3/4"	1/2"	3/4"	2"
STEAMER *23	138	1/2"	1/2"	3/4"	-
STEAMER *23	138	1/2"	1/2"	3/4"	-

ADDENDUM REFERENCE DRAWING: M-107

SHEET TITLE:  
PHASE-2 BLDG-3, 1ST FLOOR MECHANICAL

PROJECT: REHABILITATE FOOD SERVICE OPERATIONS  
BUILDING NOS. 3 & 20

WARNING: THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.

DWG NO:  
SKM-3



NYS OFFICE OF GENERAL SERVICES

Serving New York

CONTRACT: HVAC

PROJ. NO: 43704-H

DATE: 06/14/12

DRAWN: ARL

APPROVED:



KIDNEY ARCHITECTS

200 John James Audubon Parkway  
Buffalo, New York 14228  
716-636-9700 Fax: 716-636-9783

KIDNEY ARCHITECTS, P.C.  
ARCHITECTS, PLANNERS  
INTERIOR & LANDSCAPE DESIGN  
EA PROJECT: 2008058.00



ENGINEERING P.C.

MECHANICAL/ELECTRICAL  
ENGINEERING CONSULTANTS  
WATERFRONT VILLAGE CENTER  
SUITE 300, 60 LAKEFRONT BOULEVARD  
BUFFALO, NY 14202  
(716)845-5092 FAX: (716)845-0187  
M/E JOB 08159