



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 43753

**CONSTRUCTION WORK, ELECTRIC WORK
PROVIDE STORM DRAINAGE IMPROVEMENTS &
WATER DISTRIBUTION & SEWER
COLLECTION SYSTEM REPLACEMENTS
ALLEN RESIDENTIAL CENTER
AND YOUTH LEADERSHIP ACADEMY
56957 NYS ROUTE 10
SOUTH KORTRIGHT, NEW YORK 13842**

February 8, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK DRAWINGS

1. Drawing No. C-002, DEMOLITION NOTES,
 - a. Add Note 9. "THE CONTRACTOR IS RESPONSIBLE FOR HANDLING, CUTTING AND DISPOSAL OF ALL ASBESTOES CEMENT (AC) PIPE TO BE REMOVED OR CUT IN ACCORDANCE WITH ALL APPLICABLE LAWS, RULES AND REGULATIONS. THE COST OF HANDLING AND REMOVAL OF AC PIPE SHALL BE INCLUDED IN THE CONTRACTORS BID.
2. Drawing No. C-117:
 - a. Label existing Forcemain discharging into MH 11 as "2" PVC FM".
3. Drawing No. C-200:
 - a. CB 1- EXISTING HEADWALL STORM SEWER PROFILE: Label existing Forcemain crossing at Station 2+05 as "2" PVC FM".
 - b. CB 1- MH 22A STORM SEWER PROFILE: Label existing Forcemain crossing at Station 2+50 as "2" PVC FM".
4. Drawing No. S-101, ALUMINUM GRATING SUPPORT DETAIL:
 - a. Delete Note: " AL.CHECKERED PLATE AS NOTED ON PLANS VIEW THIS SHEET WELD TO GRATING"

END OF ADDENDUM

James Dirolf, P.E.
Director of Design