



ADDENDUM NO. 2 TO PROJECT NO. 44003

**ELECTRICAL WORK
PROVIDE SITE ELECTRIC
DISTRIBUTION – PHASE 2
CREEDMOOR PSYCHIATRIC CENTER
80-45 WINCHESTER BLVD
QUEENS VILLAGE, NEW YORK**

January 20, 2012

<p>NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.</p>

SPECIFICATIONS

1. SPECIFICATION SECTION 01- 4100 REGULATORY REQUIREMENTS: Discard the Section bound in the Project Manual and substitute the accompanying Section noted “Revised 01/19/2012”.
 - Article 1.03B “Obtain a New York Board of Fire Underwriters inspection and certificate.” has been deleted as it is not required.
 - Article 1.04 NEW YORK CITY PERMITS AND INSPECTIONS had been deleted as it is not required.

DRAWINGS

2. Drawing No. E-101:
 - a. LEAD PAINT NOTES, amend note to read as follows:

“LEAD-BASED PAINT HAS BEEN IDENTIFIED ON THE VARIOUS SURFACES AND BUILDING COMPONENTS INCLUDED IN THE WORK AS DETAILED IN THE LIMITED LEAD BASED PAINT SURVEY REPORT PROVIDED IN THE PROJECT MANUAL APPENDIX. TAKE ALL NECESSARY PRECAUTIONS TO AVOID THE SPREAD OF LEAD CONTAINING DUST DURING DEMOLITION ACTIVITIES. REFERENCE SPECIFICATION **SECTION 02 8304.**”

3. Drawing No. E-104:
LEAD PAINT NOTES, amend note to read as follows:

“LEAD-BASED PAINT HAS BEEN IDENTIFIED ON THE VARIOUS SURFACES AND BUILDING COMPONENTS INCLUDED IN THE WORK AS DETAILED IN THE LIMITED LEAD BASED PAINT SURVEY REPORT PROVIDED IN THE PROJECT MANUAL APPENDIX. TAKE ALL NECESSARY PRECAUTIONS TO AVOID THE SPREAD OF LEAD CONTAINING DUST DURING DEMOLITION ACTIVITIES. REFERENCE SPECIFICATION **SECTION 02 8304.**”

4. Drawing No. E-105:
LEAD PAINT NOTES, amend note to read as follows:

“LEAD-BASED PAINT HAS BEEN IDENTIFIED ON THE VARIOUS SURFACES AND BUILDING COMPONENTS INCLUDED IN THE WORK AS DETAILED IN THE LIMITED LEAD BASED PAINT SURVEY REPORT PROVIDED IN THE PROJECT MANUAL APPENDIX. TAKE ALL NECESSARY PRECAUTIONS TO AVOID THE SPREAD OF LEAD CONTAINING DUST DURING DEMOLITION ACTIVITIES. REFERENCE SPECIFICATION **SECTION 02 8304.**”

5. Drawing No. E-107:
LEAD PAINT NOTES, amend note to read as follows:

“LEAD-BASED PAINT HAS BEEN IDENTIFIED ON THE VARIOUS SURFACES AND BUILDING COMPONENTS INCLUDED IN THE WORK AS DETAILED IN THE LIMITED LEAD BASED PAINT SURVEY REPORT PROVIDED IN THE PROJECT MANUAL APPENDIX. TAKE ALL NECESSARY PRECAUTIONS TO AVOID THE SPREAD OF LEAD CONTAINING DUST DURING DEMOLITION ACTIVITIES. REFERENCE SPECIFICATION **SECTION 02 8304.**”

END OF ADDENDUM

SECTION 014100

REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 COMPLIANCE

- A. Comply with applicable regulatory requirements and various codes referenced in these specifications. Where conflicts exist between local, State, and/or Federal regulatory requirements, codes, or these specifications advise the Director's Representative. The Director's Representative will assist in resolving the conflicts to the satisfaction of the regulatory agencies prior to commencing the Work.

1.02 CODES

- A. The referenced codes shall be the date of latest revision in effect at the time of receiving bids, unless the date is given.
- B. Electrical Work: Conform to the requirements of the Electrical Code of the City of New York.

1.03 PERMITS AND INSPECTIONS

- A. A New York Board of Fire Underwriters inspection or certificate is not required.
- B. The Contractor or sub-contractor performing site work which disturbs the site shall submit an executed and completed Contractor Certification Statement to the Director's Representative prior to the commencement of work. This required document is found in the Appendix. The failure to execute this required document may result in the Contract being considered for Termination for Cause under the provisions of Article 13 of the General Conditions.

1.04 LISTINGS

- A. Equipment and materials for which Underwriters' Laboratories, Inc. (UL) provides product listing service, shall be listed and bear the listing mark.
 - 1. Alternately, ETL Testing Laboratories, Inc. Product Safety Testing Listing is acceptable if the listed product has been tested to the applicable UL Standard.

1.05 FIRE RESISTANT CONSTRUCTION MATERIALS AND ASSEMBLIES

- A. Conform to the fire rating classifications based upon the test methods and acceptance criteria in the Standard, Fire Tests of Building Construction and Materials for which Underwriters' Laboratories, Inc. (UL) provides listings.
 - 1. Materials and assemblies shall comply with the acceptance criteria, detailed description of the assembly, its performance in the fire test and other pertinent details such as specification of materials, Classification coverage, and alternate assembly details.
 - 2. Alternatively, fire resistance rating classifications by other issuing organizations listed in the New York State Uniform Fire Prevention and Building Code are acceptable.

1.06 UTILITIES

- A. Underground Utilities:
 - 1. Locate existing underground utilities prior to commencing excavation work. Determine exact utility locations by hand excavated test pits. Support and protect utilities to remain in place.
- B. Coordination With Gas Utility Company:
 - 1. Comply with Con Edison Company of New York (Con Ed) requirements for new or modified gas service. If a meter is required to complete the Work, arrange installation with the Con Ed Energy Services Department.
 - a. Queens: (718) 275-3012 or (718) 275-3075.

PART 2 PRODUCTS (Not Used)

PART 3 EXECUTION (Not Used)

END OF SECTION