



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44182

**HEATING WORK
PROVIDE VENTILATION SYSTEM
VOCATIONAL SMALL ENGINE SHOP
GROVELAND CORRECTIONAL FACILITY
SONYEA ROAD ROUTE 36
SONYEA, NY**

March 18, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

HVAC WORK DRAWINGS

1. Drawing M-104, INSTALLATION NOTES: Add the following note to the installation notes.
“12. ERU Structural Support Platform
 - a. Verify approved unit dimensions prior to fabrication and provide an all welded frame per AWS standards. Attach ERU to platform per manufacturer’s instructions or as approved by Director’s Representative. Prep, prime and paint per Spec. section 099103 or provide galvanized frame as approved.
 - b. Support columns: (4) HSS 2” x 2” x 1/8” with 6” SQ. x 1/4” thick plate footers. Furnish openings and install (2) 3/8” dia. expansion bolts per plate with minimum 2” embed. Support columns are approx. 12” in height. Support Frame: (4) sides HSS 4”x4”x1/4”.””

END OF ADDENDUM

James Dirolf, P.E.
Director of Design