



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44184

**CONSTRUCTION WORK, HVAC WORK AND ELECTRICAL WORK
PROVIDE VENTILATION, MAIN SCHOOL BUILDINGS
VARIOUS DOCCS FACILITIES**

March 18, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION SPECIFICATIONS

1. Page 074113-10, Subparagraph 2.01 B. 5. a: Change “3” to “1 ½” .

CONSTRUCTION WORK DRAWINGS

2. Drawing No’s A-101, A-102, A-103, A-503, A-601, S-201, S-202, S-203, Change all References to Underslab and Foundation Wall Insulation to Read: “2 INCHES THICK”.
3. Drawing No’s A-601, Detail No. 9, Change: 18” x 18” to 24”x 24”.
4. Drawing No’s C-101, Detail Riverview Note 5.d; change depth of “one foot” to “two feet”.

HVAC CONTRACT

5. No work this Addendum.

ELECTRICAL CONTRACT

6. No work this Addendum.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design