



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44202**

**ELECTRICAL WORK  
REPLACE ELECTRIC SERVICE  
MAINTENANCE HEADQUARTERS  
DOT REGION 4, GENESEE COUNTY  
5441 EAST MAIN STREET  
BATAVIA, NY 14020**

April 23, 2012

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

1. Drawing No. E-101:
  - a. PART SITE PLAN: AT THE COLD STORAGE BUILDING: Add circuit label "One 2 1/2" conduit with 4#4/0 & 1#1/0 EGC and one 1 1/2" conduit with 4 #2 & 1 #6 EGC" to identify the conduit between pullbox P-4 and PP-cold.
  - b. PART SITE PLAN: Change the circuit label between pullbox P-4 and P-3 to read, "One 2 1/2" conduit with 4#4/0 & 1#1/0 EGC and one 1" conduit with 4 #2 & 1 #2 EGC. ((ABOUT 200' between PP-COLD and P-3(BLACK-TOP AREA))"
  - c. PART SITE PLAN: Add leader "Provide surface mounted 100A, 50ATE Main Circuit Breaker, 120/208 Volt, 12 pole, NEMA 3R Load Center" to the power panelboard next to the pullbox P-2. Label the power panelboard "LOAD CENTER".
  - d. PART SITE PLAN: Label the power panelboard "PP-BRINE" next the pullbox P-3.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design