



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 6 TO PROJECT NO. 44220

**Construction Work
Provide Conversion of 4th Floor to Wet Lab, Building No. 4
New York Psychiatric Institute
1051 Riverside Drive
New York, NY 10032**

February 07, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATION GROUP

1. Page 230900 – 2, Change Paragraph 1.5.A.9 to Read:
9. Provide all BMS control wiring in conduit.
2. Page 230900 – 2, Change Paragraph 1.5.A.10 to Read:
10. Provide all work for free cooling mode. Refer to section 230993 for details.
3. Page 230900 – 2, Delete Paragraph 1.5.A.11 .
4. Page 230900 – 2, Change Paragraph 1.5.A.12 to Read:
12. Provide all available software points from each new installed VFD drive via BACnet communication interface.
5. Page 283105 – 1, Article 1.01 ALLOWANCES: Delete in its entirety.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design