



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44257**

**CONSTRUCTION WORK & ELECTRIC WORK  
REPLACE EPDM & SHINGLE ROOFS  
CELL BLOCK BUILDINGS 2 & 4  
ATTICA CORRECTIONAL FACILITY  
639 EXCHANGE STREET  
ATTICA, NY**

July 12, 2012

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION WORK**

1. **DOCUMENT 007307** - Correct 16.7 Contract Goals, 16.7.1 to read:  
OGS hereby establishes an overall goal of 9% for MWBE participation, 5% for Minority-Owned Business Enterprises ("MBE") participation and 4% for Women-Owned Business Enterprises ("WBE") participation (based on the current availability of qualified MBEs and WBEs).
2. **DOCUMENT 075323** – Add 2.07.C to read:  
C. Self- adhering Vapor Retarder:
  1. 40 mil minimum composite consisting of 35 mils of self adhering rubberized asphalt laminated to a 5 mil skid resistant polyethylene film. Existing deck shall be primed in accordance with manufacturer's specifications.

**DRAWINGS**

**ELECTRICAL WORK DRAWINGS**

3. Drawing No. E-101:
  - a. Under General Notes and Specific Notes, revise "(This Drawing Only)" to read : "For Drawings E-101 & E-102)".

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design