




STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 5 TO PROJECT NO. 44281**

**CONSTRUCTION WORK  
REPAIR CONCRETE PERIMETER WALL AND EXTERIOR OF BUILDINGS 9, 10, & 11  
SING SING CORRECTIONAL FACILITY  
354 HUNTER STREET  
OSSINING, NY**

February 3, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION DRAWINGS**

1. Drawing No. S-107:
  - a. Detail 2, REINFORCEMENT AND SURFACE PREPARATION NOTES, NOTE 2; Add the following to the end of the note; "FOR BIDDING PURPOSES, ASSUME REBAR CORROSION WITH GREATER THAN 25% SECTION LOSE OCCURS AT 20% OF THE REBAR EXPOSED BY THE LINTEL/SPANDREL BEAM REPAIRS ONLY."

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design