



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44288

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, ELECTRICAL WORK
REPAIR UNDERGROUND STEAM TUNNELS
WILLARD DRUG TREATMENT CENTER
7116 COUNTY ROUTE 132
WILLARD, NY**

March 1, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION DRAWINGS

1. Drawing G-102, Replace uppermost right hand note with the following:

"CONSTRUCTION CONTRACTOR TO PROVIDE 350'-0" OF TRENCH FOR 5" UNDERGROUND STEAM LINE AND 1" CONDENSATE LINE, COORDINATE W/ H TRADE CONTRACT."

HVAC SPECIFICATIONS

1. DOCUMENT 000110 TABLE OF CONTENTS:
 - a. Remove "002216 Supplementary Instructions To Bidders – Asbestos Projects" under "BIDDING REQUIREMENTS" heading.
2. SECTION 002216: Remove SECTION 002216 from the Project Manual.
3. SECTION 014100: Replace SECTION 014100 in the Project Manual with the accompanying section 014100, printed 3/01/2013 (1 page).

HVAC DRAWINGS

1. No revisions.

PLUMBING SPECIFICATIONS

1. DOCUMENT 000110 TABLE OF CONTENTS:
 - a. Remove "002216 Supplementary Instructions To Bidders – Asbestos Projects" under "BIDDING REQUIREMENTS" heading.

ADDENDUM NO. 2 TO PROJECT NO. 44288

2. SECTION 002216: Remove SECTION 002216 from the Project Manual.
3. SECTION 014100: Replace SECTION 014100 in the Project Manual with the accompanying section 014100, printed 3/01/2013 (1 page).

PLUMBING DRAWINGS

1. Drawing P-001, PUMP OPERATION DETECTION SYSTEM, Replace upper left note with the following:

"ELECTRICAL RECEPTACLE BOX UNDER THE ELECTRICAL CONTRACT"

ELECTRICAL SPECIFICATIONS

1. DOCUMENT 000110 TABLE OF CONTENTS:
 - a. Remove "002216 Supplementary Instructions To Bidders – Asbestos Projects" under "BIDDING REQUIREMENTS" heading.
2. SECTION 002216: Remove SECTION 002216 from the Project Manual.
3. SECTION 014100: Replace SECTION 014100 in the Project Manual with the accompanying section 014100, printed 3/01/2013 (1 page).

ELECTRICAL DRAWINGS

2. No revisions.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design

SECTION 014100

REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 COMPLIANCE

- A. Comply with applicable regulatory requirements and various codes referenced in these specifications. Where conflicts exist between local, State, and/or Federal regulatory requirements, codes, or these specifications advise the Director's Representative. The Director's Representative will assist in resolving the conflicts to the satisfaction of the regulatory agencies prior to commencing the Work.

1.02 CODES

- A. All Work shall comply with the New York State Uniform Fire Prevention and Building Code (the "Uniform Code"), which includes the current editions of Part 1222 (Plumbing Code and its referenced standards except as noted in the following paragraphs of this section.
 - 1. The above referenced codes shall be the date of latest revision in effect at the time of receiving bids, unless the date is given.

1.03 STATE REQUIRED PERMITS AND INSPECTIONS

- A. A New York Board of Fire Underwriters inspection or certificate is not required.

1.04 LISTINGS

- A. Equipment and materials for which Underwriters' Laboratories, Inc. (UL) provides product listing service, shall be listed and bear the listing mark.
 - 1. Alternately, ETL Testing Laboratories, Inc. Product Safety Testing Listing is acceptable if the listed product has been tested to the applicable UL Standard.

1.05 MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

- A. Perform Work required to remove, disturb, or repair any material that contains less than 1 percent by weight of asbestos (Trace) in accordance with all applicable OSHA regulations (29 CFR Part 1926.1101).

PART 2 PRODUCTS (Not Used)

PART 3 EXECUTION (Not Used)

END OF SECTION

SECTION 014100

REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 COMPLIANCE

- A. Comply with applicable regulatory requirements and various codes referenced in these specifications. Where conflicts exist between local, State, and/or Federal regulatory requirements, codes, or these specifications advise the Director's Representative. The Director's Representative will assist in resolving the conflicts to the satisfaction of the regulatory agencies prior to commencing the Work.

1.02 CODES

- A. All Work shall comply with the New York State Uniform Fire Prevention and Building Code (the "Uniform Code"), which includes the current editions of Part 1223 (Mechanical Code) and its referenced standards except as noted in the following paragraphs of this section.
 - 1. The above referenced codes shall be the date of latest revision in effect at the time of receiving bids, unless the date is given.

1.03 STATE REQUIRED PERMITS AND INSPECTIONS

- A. A New York Board of Fire Underwriters inspection or certificate is not required.

1.04 LISTINGS

- A. Equipment and materials for which Underwriters' Laboratories, Inc. (UL) provides product listing service, shall be listed and bear the listing mark.
 - 1. Alternately, ETL Testing Laboratories, Inc. Product Safety Testing Listing is acceptable if the listed product has been tested to the applicable UL Standard.

1.05 MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

- A. Perform Work required to remove, disturb, or repair any material that contains less than 1 percent by weight of asbestos (Trace) in accordance with all applicable OSHA regulations (29 CFR Part 1926.1101).

PART 2 PRODUCTS (Not Used)

PART 3 EXECUTION (Not Used)

END OF SECTION

SECTION 014100

REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 COMPLIANCE

- A. Comply with applicable regulatory requirements and various codes referenced in these specifications. Where conflicts exist between local, State, and/or Federal regulatory requirements, codes, or these specifications advise the Director's Representative. The Director's Representative will assist in resolving the conflicts to the satisfaction of the regulatory agencies prior to commencing the Work.

1.02 CODES

- A. Electrical Work: Conform to the requirements of the 2008 National Electrical Code (NEC) unless otherwise shown or specified. The Director will be the sole judge of the interpretation of these rules and requirements.

1.03 STATE REQUIRED PERMITS AND INSPECTIONS

- A. A New York Board of Fire Underwriters inspection or certificate is not required.

1.04 LISTINGS

- A. Equipment and materials for which Underwriters' Laboratories, Inc. (UL) provides product listing service, shall be listed and bear the listing mark.
 - 1. Alternately, ETL Testing Laboratories, Inc. Product Safety Testing Listing is acceptable if the listed product has been tested to the applicable UL Standard.

1.05 MATERIALS WITH TRACE AMOUNTS OF ASBESTOS

- A. Perform Work required to remove, disturb, or repair any material that contains less than 1 percent by weight of asbestos (Trace) in accordance with all applicable OSHA regulations (29 CFR Part 1926.1101).

PART 2 PRODUCTS (Not Used)

PART 3 EXECUTION (Not Used)

END OF SECTION