




STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44291

CONSTRUCTION WORK, HVAC WORK AND ELECTRICAL WORK

**REPLACE STEAM AND CONDENSATE RETURN LINES
BETWEEN BLDG NOS. 9 (ATTICA) & 72 (WYOMING)
WYOMING CORRECTIONAL FACILITY
3203 DUNBAR ROAD
ATTICA, NY**

MARCH 6, 2012

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

HVAC SPECIFICATIONS

1. Page 015123-2, Article 2.01.A.1: delete the following statement: "full modulating No. 2 oil burner and flame safeguard system." Add the following: full modulating natural gas burner and flame safe guard system.

HVAC DRAWINGS

1. Drawing M-501 Detail 4: Reduce insulation thickness to 3 inches.

ELECTRICAL CONTRACT

1. No work this addendum.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design