



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 3 TO PROJECT NO. 44303**

**HVAC WORK AND ELECTRICAL WORK**

**REPLACE ABOVE GROUND HOT WATER PIPING  
MARCY CORRECTIONAL FACILITY**

March 7, 2013

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**HVAC WORK SPECIFICATIONS**

1. Article 232006, Part 2, Add the following paragraph:

**2.06 VENTURI FLOW DEVICE**

A. Features:

1. Body: Carbon steel ASTM A-120 with ANSI B15.6 class 150 flanged ends.
2. Design: Throat signal, piezo ring, 120 degree, 3-port averaging with SuperSeal Pressure/Temperature port. Provide butterfly valve type BF-HP, per Specification Section 230523, downstream of venturi device for flow balancing.
3. Pressure Rating: 240 PSIG at 250 degrees F.
4. Accuracy: +/- 1%
5. Manufacturer: Flow Design, Model VF or equal.

2. Article 230523 3.04. A. 5. c, Delete "Flanged end".

**ELECTRICAL CONTRACT**

3. No work this addendum.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design