



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. 44309**

**CONSTRUCTION WORK  
REPAIR EXTERIOR MASONRY SURFACE, HOUSING & GYM  
BUILDING NO. 2  
MORIAH CORRECTIONAL FACILITY  
COUNTY ROUTE 7  
P.O. BOX 999  
MINEVILLE, NY**

March 15, 2012

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION WORK DRAWINGS**

1. Drawing S-101:
  - a. North Elevation & South Elevation: In common note "Existing Cementitious ... See Note 3", replace "Two Coats" with "One Coat".
  - b. West Elevation: In right hand note "Existing Cementitious ... See Note 3", replace "Two Coats" with "One Coat".
2. Drawing S-101:
  - a. West Elevation: Replace note "Remove Roof ... for Repair", with "Remove Roof and Underlayment to Steel Framing. Leave Steel Framing and Flashing Intact. See Roof Plan View for Repair."

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design