



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 3 TO PROJECT NO. 44322

**CONSTRUCTION WORK, HVAC WORK, ELECTRICAL WORK
RENOVATE FREEZERS and COOLERS & CONSTRUCT CANOPY ROOF
BLDG. No. 111
WATERTOWN CORRECTION FACILITY
23147 SWAN ROAD
WATERTOWN, NEW YORK**

April 19, 2012

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

DRAWINGS

1. Drawing No. A-101:
 - a. Note 4: Replace by “H” Contractor and substitute the following; by “C” Contractor. The temporary trailer is to be provided by the “C” Contractor.
 - b. Add the following to Note 4: Provide temporary 100A, 208/120V 3 phase 4 wire 12 ckt panel board with 100A MCB in trailer as shown on plans. Provide branch circuits to serve temporary flood light and temporary trailer equipment. Verify exact size of branch circuit breakers and types of connections with contractor providing temporary trailer.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design