



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. 44334**

**CONSTRUCTION WORK  
PROVIDE CELL LOCKING SYSTEM  
HOUSING UNIT  
BUILDING NO. 81  
TACONIC CORRECTIONAL FACILITY  
250 HARRIS ROAD  
BEDFORD HILLS, NY**

March 21, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.  
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**DRAWINGS**

1. Drawing A-501: At STEEL PLATE LOCK BOX (RHRB SHOWN) DETAIL;  
Section B: Delete all reference to 1/8" thick steel plate. Provide 3/16" steel plate lock box as/per Section A.
  
2. Drawing A-101: Change SPECIFIC NOTE 4. to read as follows;
  4. PROVIDE THE FOLGER ADAM MODEL 122MC-1-04 X 120V AC HALF-CYCLE DEADLATCH WITH SOUTHERN STEEL MODEL 200MRS-TB MAGNETIC DOOR POSITION SWITCH. PROVIDE DOOR PULL/STRIKE/ASTRAGAL ASSEMBLY AT CORRIDOR SIDE. PROVIDE RECESSED DOOR PULL ON INMATE SIDE AS SPECIFIED. PROVIDE CONTROL PANELS IN WALL MOUNTED CONTROL CABINETS AND CONTROL WIRING AT EACH FLOOR. COORDINATE LOCATIONS WITH ELECTRICAL DRAWINGS.

**END OF ADDENDUM**

Margaret F. Larkin  
Acting Executive Director