



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44346

**HVAC WORK
PROVIDE UPGRADE TO HEATING SYSTEM
MAINTENANCE SUBHEADQUARTERS
DOT REGION 8, COLUMBIA COUNTY
941 ROUTE 23
CRARYVILLE, NY**

May 1, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

H CONTRACT:

SPECIFICATIONS

DRAWINGS:

1. Drawing No. M-101:
 - a. Note Column, add note 4 to Read:

“4. Condensate Tank and Pump”

2. Drawing No. M-101:
 - a. First Floor Plan, add General Note to Read:

“1. Piping located above hard ceiling to be abandoned in place.

3. Drawing No. M-102:
 - a. First Floor Plan, add General Note to Read:

“1. Run supply and return piping below hard ceiling, anchored to wall, in central core area of building.”

END OF ADDENDUM

James Dirolf, P.E.
Director of Design