



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44350

**CONSTRUCTION WORK
PROVIDE INSTALLATION OF VALVES AND
CHLORINE INJECTION SYSTEM
WOODBOURNE CORRECTIONAL FACILITY
WOODBOURNE, NY 12788**

February 28, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

BIDDING REQUIREMENTS

1. Page 002219 – 1, Change the information after the first sentence in Paragraph 25.1 to read:
“Regional Supervisor Name: John Potter
Address: 48 McKendrick Road, P.O. Box 446, Wallkill NY 12589-0446
Phone: (845) 895-3170
Email: Region3preawardsubmittals@ogs.ny.gov”

SPECIFICATIONS

2. Page 011000 – 1, Article 1.04: Delete this article.
3. Page 464600 – 4, Paragraph 3.02 G.: Delete this paragraph.

DRAWINGS

4. Drawing No. C-103:
 - a. Detail 1: The length dimension of the sump shall be 5'-4" instead of 7'-0".
5. Drawing No. C-105:
 - a. Detail 2: The callout for providing tank access hatch shall refer to detail 3 on drawing C-105 instead of detail 3 on drawing C-106.
 - b. Notes under detail 2: In Note 1, replace the text at the end of the sentence "(see spec section 331616)" with the following: "(see spec section 444246)".

6. Drawing No. C-108:
 - a. Detail 2: The cross-section view reference to detail 3/C-108 is incorrect. The correct reference should be detail 4/C-108.

7. Drawing No. E-101:
 - a. Notes for detail 2: Modify the notes by replacing the wording: "Provide Paragon Electrical Products model EL 7200/120 of approved equal" with: "Provide Paragon Electrical Products model EL 7200/120, Intermatic ET70215C, Tork model DTS200A, or approved equal."

END OF ADDENDUM

James Dirolf, P.E.
Director of Design