



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 7 TO PROJECT NO. 44500

**HVAC WORK, ELECTRICAL WORK
REHABILITATE HEATING SYSTEM
BUILDING NO. 18
AUBURN CORRECTIONAL FACILITY
135 STATE STREET
AUBURN, NEW YORK**

March 24, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

HVAC AND ELECTRIC WORK SPECIFICATIONS

1. SECTION 013119 PROJECT MEETINGS: 1.04A4: add "Facility Representative" to this sentence.
2. SECTION 013119 PROJECT MEETINGS: 1.05B: Add "Facility Representative" to list of meeting attendees.
3. SECTION 017000 CONTRACT CLOSEOUT: Add "1.08. MATERIAL SAFETY DATA SHEETS: A. Provide Material Safety Data Sheets for all water treatment chemicals, paints, floor coverings, adherents, glues, sealants, oils, lubricants, coatings, and all other gels, liquids and gases provided or present in the construction phase."

HVAC WORK SPECIFICATIONS

4. SECTION 028213 ASBESTOS ABATEMENT: 1.03D: delete paragraph in entirety.
5. SECTION 230923 DIRECT DIGITAL BUILDING CONTROL SYSTEM: 2.02Bf2: delete "or 8".

HVAC WORK DRAWINGS

6. DRAWING M-301, Detail 3: Provide 1" bypass with 2 gate valves around cold water service PRV-18 and PRV isolation gate valves..

END OF ADDENDUM

Margaret F. Larkin
Acting Executive Director