



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44506

**ELECTRICAL WORK
REPLACE ELECTRICAL SWITCHGEAR
BUILDING NO. 20
RIVERVIEW CORRECTIONAL FACILITY
1110 TIBBITS DRIVE PO BOX 158
OGDENSBURG, NY 13669**

March 12, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. Page 014100-1, Remove 1.03 B
2. Page -14100-2, Add 1.06 B 3 to read "The utility cost will be paid by the Field order contingency allowance."

DRAWINGS

3. Drawing No. E-101, Add General Note #4 to read:
 - a. PROVIDE PVC-80 CONDUIT FOR TEMPORARY FEEDERS.
4. Drawing No. E-601, Revise Keyed Note #8 to read:
 - a. PROVIDE A LOCKABLE, HINGED NEMA 3R CONNECTION BOX WHERE INDICATED ON PLANS. MOUNT THREE (3) TWO-WAY, 200A, 15KV LOADBREAK JUNCTIONS INSIDE CONNECTION BOX. TERMINATE CABLES FROM SWITCHGEAR WITH 200A, 15KV LOAD BREAK ELBOWS. PROVIDE GROUND LUGS SUITABLE FOR 3-#2/0 CONDUCTORS. ENCLOSURE SHALL HAVE TWO (2) 4" RGS CONDUIT NIPPLES WITH THREADED PIPE CAPS AND STAINLESS STEEL SECURING CHAINS. ENCLOSURE SHALL BE A MINIMUM OF 36" WX 36" H X 18" D, AND SHALL HAVE A LABEL STATING: "DANGER HIGH VOLTAGE" IN 2" LETTERS. PROVIDE ALL REQUIRED COMPONENTS FOR A FULLY FUNCTIONAL GENERATOR CONNECTION BOX.
5. Drawing No. E-101, Add General Note #5 to read:
 - a. TEMPORARY FEEDERS ARE TO BE INSTALLED UNDERGROUND AND SHALL BE CORE DRILLED AT EXISTING MANHOLES.

ADDENDUM NO. 1 TO PROJECT NO. 44506-E

6. Drawing No. E-101, Add General Note #6 to read:
 - a. CONTRACTOR SHALL PROVIDE PROTECTION OF TEMPORARY EQUIPMENT TO ENSURE THAT IT WILL NOT FAIL DUE TO ANY WEATHER RELATED CONDITIONS WHILE THE TEMPORARY EQUIPMENT IS IN OPERATION. THIS INCLUDES BUT IS NOT LIMITED TO ANY MEANS AND METHODS TO ELEVATE EQUIPMENT OR TO ENCLOSE ANY EQUIPMENT. PROVIDE A MINIMUM OF SIX INCHES OF CRUSHED STONE BENEATH TEMPORARY EQUIPMENT THAT EXTENDS ONE FOOT BEYOND EQUIPMENT FOOTPRINT.

7. Drawing No. E-101, Add General Note #7 to read:
 - a. PROVIDE AN EIGHT FOOT, LOCKABLE DOUBLE GATE FOR THE TEMPORARY FENCE.

8. Drawing No. E-101, Add General Note #8 to read:
 - a. PROVIDE ALL FUEL FOR TEMPORARY GENERATORS AT MAIN SERVICE AND AT EACH BUILDING.

9. Drawing No. E-101, Add General Note #9 to read:
 - a. PROVIDE SUPPORT AND SERVICE FOR TEMPORARY EQUIPMENT WITHIN EIGHT HOURS.

10. Drawing No. E-101, Add General Note #10 to read:
 - a. CONTRACTOR SHALL PROVIDE A SUBMITTAL FOR THE TEMPORARY SWITCHGEAR AND GENERATOR WITHIN 20 DAYS OF CONTRACT AWARD. CONTRACTOR SHALL INSTALL THE TEMPORARY SWITCHGEAR AND GENERATOR WITHIN 30 DAYS AFTER SUBMITTAL APPROVAL.

11. Drawing No. E-101, Add General Note #9 to read:
 - a. PROVIDE SUPPORT AND SERVICE FOR TEMPORARY EQUIPMENT WITHIN EIGHT HOURS.

12. Drawing No. E-601, Revise Keyed Note #11 to read:
 - a. PROVIDE TEMPORARY GENERATORS DURING SHUTDOWNS TO MINIMIZE OUTAGES AT BUILDINGS. SEE SPECIFICATION 015000. SIZES SHALL MATCH TRANSFORMER SIZES. ALL BUILDING TRANSFORMERS ARE 13.2KV-208/120V, $\Delta - Y$, 3 ϕ 4W. TRANSFORMERS ARE OF THE OUTDOOR, PAD-MOUNT TYPE.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design