



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44508

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, ELECTRIC WORK
REPLACE OBSERVATION TOWER-BLDG. #68
CLINTON CORRECTIONAL FACILITY
ROUTE 374, COOK STREET
DANNEMORA, NEW YORK 12929-2000**

October 03, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CLARIFICATIONS

1. Specification Section 099659: Surfaces to be painted with the high build coating system is the bathroom floor support framing and the underside of the metal decking per detail #6 on S-501. The pre-engineered tower support steel shall be hot dipped galvanized per Tower Design Criteria Note #6 on S-001. Field painting of the tower support steel is not required.
2. Drawing A-201 Detail 2: Access panels are to be provided by the plumbing contract. Specifications for the access panels are located in Section 224600 Parts 2.03.A.8 and 2.04.A.7.
3. Drawing H-101 Detail 4: Located between the shutoff and control valve is a symbol not listed on the schedule. That symbol represents a flow balancing valve.

SPECIFICATIONS

1. SECTION 003132 GEOTECHNICAL DATA – Added.
2. SECTION 031100 CONCRETE FORMWORK – Section 2.01 B: Delete Section 2.01 B.
3. SECTION 133419 PRE-ENGINEERED METAL TOWER STRUCTURE AND BUILDING – Section 2.08: Change “steel plate” to “14 gauge galvanized steel”.
4. SECTION 133419 PRE-ENGINEERED METAL TOWER STRUCTURE AND BUILDING – Section 2.08: Delete “bullet resistant”.
5. SECTION 075323 ADHERED EPDM ROOFING SYSTEM – Section 1.09 B: Change “25 Year Full System Warranty” to “30 Year Full System Warranty”.

ADDENDUM NO. 2 TO PROJECT NO. 44508

6. SECTION 102813 TOILET AND BATH ACCESSORIES – Section 2.04 A: Change Section 2.04 A to read:
“ A. Types:
 1. Type B: Polished stainless steel mirror in stainless steel frame.”
7. SECTION 102813 TOILET AND BATH ACCESSORIES – Section 2.04 C: Change “Furnish the following for mirror Type A” to “Furnish the following for mirror type B”.
8. SECTION 102813 TOILET AND BATH ACCESSORIES – Section 2.04 D: Change 2.04 D to read:
“D. Type B and B-S Mirrors: 20 gage Type 430 stainless steel, with bright annealed finish.
 1. Mirror Backing: One layer of 1/4 inch thick hardboard or particleboard backing over entire back mirror surface.
9. SECTION 102813 TOILET AND BATH ACCESSORIES – Section 2.07 A: Delete “clear glass or”.

DRAWINGS

1. Drawing No. A-201:
 - a. South Elevation: Change note reading “Access Panel (Typ)” to “Access Panel, See Plumbing (Typ)”.
2. Drawing No. A-201:
 - a. South Elevation: Delete two urinal screens, one on each side of the urinal.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design