



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 5 TO PROJECT NO. 44508

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, ELECTRIC WORK
REPLACE OBSERVATION TOWER-BLDG. #68
CLINTON CORRECTIONAL FACILITY
ROUTE 374, COOK STREET
DANNEMORA, NEW YORK 12929-2000**

October 11, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

DRAWINGS

1. Drawing No. H-001:
 - a. Strainers not required for the type of thermostatic valve called out in schedule
 - b. Follow specification which calls for gate valve for main shut off.
 - c. Delete balance valve, not required.
2. Drawing No. H-102:
 - a. Steam/trap end of main detail added.
3. Drawing No. P-101:
 - a. Provide shut-off valve at point of connection of hot and cold water supply line in corridor per specification 220523.

SPECIFICATIONS

1. SECTION 092116 GYPSUM BOARD SYSTEMS:
 - a. 2.01.A & 2.01.A.2: Replace 25 gage with 20 gage.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design