



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44547

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, AND ELECTRICAL WORK
REHABILITATE SHOWERS
MAIN HOUSING UNITS 2, 3, 5, 7,8 AND 34
CLINTON CORRECTIONAL FACILITY
ROUTE 374
COOK STREET
DANNEMORA, N.Y.**

February 26, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK DRAWINGS

1. Drawing No.S-100:
 - a. Detail 4 TYPICAL CLOSURE PLATE ANGLE FASTENING: Move this Detail to Drawing P-404.

2. Drawing No.A-401:
 - a. Detail 1/A-401: Add the following:
“NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE.”
 - b. Detail 2/A-401: Add the following:
“NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE.”
 - c. Detail 4/A-401: Add the following:
“NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE.”

PLUMBING WORK DRAWINGS

3. Drawing No. P-401:
 - a. Detail 1/P-401: Delete the following “NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE AT EACH UNIT.”
 - b. Detail 2/P-401: Delete the following “NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE AT EACH UNIT.”

- c. Detail 4/P-401: Delete the following “NOTE: ASSUME THERE WILL BE 1.5 SQFT OF PATCHING OF THE BOILER PLATE STEEL DUE TO REMOVAL OF SHOWER HEAD, MIXING VALVE, AND SANITARY DRAIN PIPE AT EACH UNIT.”

- 4. Drawing No. P-404:
 - a. Detail 1/P-404: Change the Note, “SEE STRUCTURAL DWGS. FOR TYPICAL WELD” to read “SEE TYPICAL CLOSURE PLATE ANGLE FASTENING DETAIL THIS DRAWING”.
 - b. Detail 4/P-404: Change the Note, “SEE STRUCTURAL DWGS. FOR TYPICAL WELD” to read “SEE TYPICAL CLOSURE PLATE ANGLE FASTENING DETAIL THIS DRAWING”.
 - c. Detail 5/P-404: Change the Note, “SEE STRUCTURAL DWGS. FOR TYPICAL WELD” to read “SEE TYPICAL CLOSURE PLATE ANGLE FASTENING DETAIL THIS DRAWING”.
 - d. Add the following NOTES:

“STRUCTURAL STEEL FABRICATION / ERECTION NOTES:
 - 1. STRUCTURAL STEEL COMPONENTS SHALL BE FABRICATED BY A SHOP OR FABRICATOR WITH MINIMUM OF FIVE YEARS EXPERIENCE SPECIALIZING IN THIS WORK.
 - 2. ALL WELDING SHALL BE PERFORMED BY PERSONNEL WITH CURRENT AWS CERTIFICATION FOR THE TYPE OF WORK PERFORMED.
 - 3. DO NOT BEGIN STEEL FABRICATION UNTIL STEEL SHOP DRAWINGS HAVE BEEN APPROVED BY DIRECTOR'S REPRESENTATIVE.
 - 4. VENTILATE WORK AREAS DURING FIELD WELDING AND OTHER WORK GENERATING SMOKE, VAPORS, AND ODORS IN CONFORMANCE WITH OSHA 1926.353. EXHAUST SHALL BE DISCHARGED TO THE BUILDING EXTERIOR AND SHALL NOT ADVERSELY AFFECT ANY ADJACENT AIR INTAKES FOR OTHER BUILDING VENTILATION.
 - 5. DO NOT BEGIN WORK BEFORE A FIRE CONTROL PLAN, APPROVED BY DIRECTOR'S REPRESENTATIVE IS IN PLACE. DO NOT DEVIATE FROM THE APPROVED FIRE CONTROL PLAN AT ANY TIME.
 - 6. MAINTAIN A FIRE WATCH FOR A MINIMUM OF 4 HOURS AFTER ALL COMPLETION OF ANY FIELD WELDING, ABRASIVE CUTTING, OR SPARK PRODUCING PROCEDURE.
 - 7. DO NOT FLAME CUT ANY MATERIAL ON PROJECT.”
 - e. Move Detail 4 from Drawing S-100 to this Drawing.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design