



ADDENDUM No. 2 TO PROJECT No. 44562

**CONSTRUCTION WORK, HVAC WORK, ELECTRIC WORK
RECREATION AREA EXPANSION,
RMU, BUILDING No.126
AND SITEWIDE CCTV UPGRADE
BEDFORD HILLS CORRECTIONAL FACILITY
247 HARRIS ROAD
BEDFORD HILLS, NEW YORK 10507-2400**

January 15, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK SPECIFICATION

1. SECTION 310140 MAINTANANCE OF SHORING AND UNDER PINNING
 - a. Remove Specification Section 310140 in its entirety from Contract Documents.

ELECTRICAL WORK SPECIFICATION

1. SECTION 282306 CCTV/AUDIO MONITORING EQUIPMENT:
 - a. Page 282306-15, Paragraph 2.01, I, 7: Change Paragraph to read as follows:

“7. Top of Rack Mounted Exhaust Fan: Middle Atlantic Products Model FAN-6 fan with fan guards (Model GUARD-6) on both sides and accessories as required for mounting.
 - a. Exhaust fans shall be cord and plug connected.”
 - b. Page 282306-15, Article 2.01: Add the following Paragraph:

“K. Retrofit Rack Top Mounted Exhaust Fan: Middle Atlantic Products Model FAN-6 fan with fan guards (Model GUARD-6) on both sides and accessories as required for mounting.
 1. Exhaust fans shall be cord and plug connected.
 2. Install exhaust fans on a 10”x10” galvanized steel plate (minimum 16 gauge) for retrofit mounting on top of existing Electronic Equipment Rack (EER) as indicated on drawings.”
 - c. Page 282306-16, Subparagraph 2.02, A, 5: Change Subparagraph to read as follows:

“5. Accessories: Provide all materials and work as required for the mounting of the exterior camera stations.”

DRAWINGS

2. Drawing No. C-101:
 - a. Test Hole Data, Add the following General Note:
 - “1. The vertical dimension of the existing Steam Tunnel is approximately 7’-6” +/- from Top of Tunnel to Bottom of Tunnel.”
3. Drawing No. C-105:
 - a. Detail 1/C-105: Delete to be removed symbols from two (2) existing electric lines. The two (2) existing electric lines are to remain in place.
4. Drawing No. E001:
 - a. Add the following General Note:
 - “R. RETROFIT RACK TOP MOUNTED EXHAUST FANS IN EXISTING ELECTRONIC RACKS (EER) ARE TO BE CONNECTED TO THE EXISTING POWER RECEPTACLE (DUPLEX OR QUAD) WITHIN EXISTING EER.”

END OF ADDENDUM

James Dirolf, P.E.
Director of Design