



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44569**

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, ELECTRIC WORK**

**MODIFY VISIT ROOM CONTROL ROOMS  
BUILDING NUMBER 1  
EASTERN CORRECTIONAL FACILITY  
30 INSTITUTION ROAD  
NAPANOCH, NY**

May 1, 2015

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION SPECIFICATIONS**

1. SECTION 111901-1.07F: Change number of site inspections in addition to Post Installation Inspection to be Two in lieu of four.
2. SECTION 111901-2.05E: Delete this subsection entirely. No Baton Pass required.
3. SECTION 111901-2.06G8: Change to surface mounted rigid ferrous metal conduit in lieu of PVC Schedule 40 conduit.

**CONSTRUCTION DRAWINGS**

4. DRAWING No. A-401, ENLARGED MAIN CONTROL ROOM PLAN:
  - a. Room 03-SALLYPORT. Change Elevation marker inside room to read E/A-601 (shows elevation of door 03A) Change Elevation marker outside room to read D/A-601 (shows elevation of door 03B).
  - b. Room 02-CONTROL ROOM. Add note to read: 'HSS 6x6x1/4 AT CORNERS TYPICAL' with arrows pointing to the two corners of the room at wall adjacent to Control Panel.
5. DRAWING No. A-402, ELEVATIONS AT CONTROL ROOM AND SALLYPORT:
  - a. Elevation H. Change note: FRAME TYPE D-1 to read, FRAME TYPE C.
  - b. Elevation G. Change note: FRAME TYPE D to read, FRAME TYPE C.
  - c. Elevations A,B,C,D. Add note: '3/16" STEEL PLATE ON HSS 2X6X1/4 SUPPORT FRAME TYPICAL, SEE PARTITION TYPE P3 ON PAGE A-401'

6. DRAWING No. A-601, DOOR SCHEDULE :
  - a. Door number 01B: Change HEAD and JAMB details from: 7/A-601 and 14/A-601 to: H/A-603 and E/A-603 respectively. Add note: 'SEE DETAILS A-603' in remarks column.
  - b. Door number 03A: Change Frame type from: F to E. Delete Head and Jamb detail nomenclature (7/A-601 and 8/A-601) entirely. Add note: 'SEE DETAILS A-604' in Remarks column.
  - c. Door number 03B: Change Frame type from: E to D. Delete Head and Jamb detail nomenclature (7/A-601 and 8/A-601) entirely. Add note: 'SEE DETAILS A-604' in Remarks column.
  - d. Door number 10A: Change Frame type from: D-1 to C.
  - e. Door number 11A Change Frame type from: D to C
  
7. DRAWING No. A-601, Detail4/A-601, FRAME TYPES:
  - a. Frame type A-1 change detail marker14/A-601 to read: E/A-603
  - b. Omit frame type marker D-1
  - c. Add note at Frame types D and E to read: 'SEE LOCK DETAILS A-604' add second note to read: 'HSS 2x6x1/4 TUBE FRAME WITH 3/16" STEEL PLATE BOTH SIDES, SEE DETAILS A-604'

**END OF ADDENDUM**

Margaret F. Larkin  
Executive Director