




STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 4 TO PROJECT NO. 44578

**CONSTRUCTION WORK - PLA
MAJOR BUILDING RENOVATIONS FOR THE
MANHATTAN FORENSIC
RELOCATION
MANHATTAN PSYCHIATRIC CENTER
600 EAST 125th STREET
WARDS ISLAND, NY 10035**

August 14, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONTRACTING REQUIREMENTS

1. DOCUMENT 001117 ADVERTISEMENT FOR BIDS:
 - a. The last date for receipt of bids is changed from Wednesday, September 16, 2015, to Wednesday, September 30, 2015.
 - b. The dates of the Mandatory Pre-Bid Conference and Site Visits are changed from 10:00 a.m. August 19, 2015 and 10:00 a.m. September 3, 2015 to 10:00 a.m. September 3, 2015 and 10:00 a.m. September 17, 2015 at Manhattan Psychiatric Center, TDX Field Office in Building 106 on Wards Island, NY. Prospective bidders are required to visit the site at least one of these times.

A requirement to attend the Mandatory Pre-Bid Conference & Site Visit is to phone the office of Irene Rosa, (212) 369-4757 between 8:30 AM and 3:30 PM a minimum of 24 hours in advance of the date to provide the names of those who will attend the Mandatory Pre-Bid Conference and Site Visit, and which date they will be in attendance.

SPECIFICATIONS

2. SMOKE DAMPER ACCEPTANCE CHECKLIST SCHEDULE: Insert the accompanying Sample Damper Acceptance Checklist into the Appendix of Volume 1 and is to be used to assist the quality assurance of Smoke and Combined Fire and Smoke Damper installations.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction

SMOKE DAMPER SCHEDULE

#	TAG	SYSTEM SERVED	FLOOR	TYPE	Room #	Column lines	DUCT HEIGHT (IN.)	DUCT WIDTH (IN.)	REMARKS	Framing		Retaining Angle		Annular space		Actuator position/location		Duct access door		Access to Actuator Duct access door and Duct smoke detector		Confirm Actuator stroke		Duct mounted Smoke detector Installed/location		Duct mounted Smoke detector wired		Duct mounted Smoke detector Programmed /Tested	
										Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By	Date checked	Checked By
1	SD-102-1-1	AHU-102-2-1	FIRST FLOOR	SD			14	26																					
2	SD-102-1-2	GEF-102-2-1	FIRST FLOOR	SD			16	16																					
3	SD-102-1-3	TEF-102-17-1	FIRST FLOOR	SD			8	10																					
4	SD-102-1-4	TEF-102-3-3	FIRST FLOOR	SD			8	10																					
5	SD-102-1-5	AHU-102-2-1	FIRST FLOOR	SD			8	12																					
6	SD-102-1-6	AHU-102-2-1	FIRST FLOOR	SD			6	10																					
7	SD-102-1-7	AHU-102-2-1	FIRST FLOOR	SD			10	16																					
8	SD-102-2-1	AHU-102-2-1	SECOND FLOOR	SD			26	60	PROVIDED BY AHU MFG																				
9	SD-102-2-2	AHU-102-2-1	SECOND FLOOR	SD			84	24	PROVIDED BY AHU MFG																				
10	SD-102-2-3	AHU-102-3-1	SECOND FLOOR	SD			10	28																					
11	SD-102-2-4	AHU-102-3-1	SECOND FLOOR	SD			10	22																					
12	SD-102-3-1	AHU-102-3-2	THIRD FLOOR	SD			18	54																					
13	SD-102-3-2	AHU-102-3-2	THIRD FLOOR	SD			14	8																					
14	SD-102-3-3	AHU-102-3-2	THIRD FLOOR	SD			16	46																					
15	SD-102-3-4	AHU-102-3-2	THIRD FLOOR	SD			20	66	PROVIDED BY AHU MFG																				
16	SD-102-3-5	AHU-102-3-2	THIRD FLOOR	SD			36	72	PROVIDED BY AHU MFG																				
17	SD-102-3-6	DVF-102-18-1	THIRD FLOOR	SD			14	14																					
18	SD-102-4-1	AHU-102-4-1	FOURTH FLOOR	SD			18	54																					
19	SD-102-4-2	AHU-102-4-1	FOURTH FLOOR	SD			14	8																					
20	SD-102-4-3	AHU-102-4-1	FOURTH FLOOR	SD			16	46																					
21	SD-102-4-4	RF-102-4-1	FOURTH FLOOR	SD			12	16																					
22	SD-102-4-5	DVF-102-18-1	FOURTH FLOOR	SD			14	14																					
23	SD-102-5-1	AHU-102-5-1	FIFTH FLOOR	SD			18	54																					
24	SD-102-5-2	AHU-102-5-1	FIFTH FLOOR	SD			14	8																					
25	SD-102-5-3	AHU-102-5-1	FIFTH FLOOR	SD			16	46																					
26	SD-102-5-4	DVF-102-18-1	FIFTH FLOOR	SD			14	14																					
27	SD-102-6-1	AHU-102-6-1	SIXTH FLOOR	SD			18	54																					
28	SD-102-6-2	AHU-102-6-1	SIXTH FLOOR	SD			14	8																					
29	SD-102-6-3	AHU-102-6-1	SIXTH FLOOR	SD			16	46																					
30	SD-102-6-4	RF-102-6-1	SIXTH FLOOR	SD			12	16																					
31	SD-102-6-5	DVF-102-18-1	SIXTH FLOOR	SD			14	14																					
32	SD-102-7-1	AHU-102-7-1	SEVENTH FLOOR	SD			18	54																					
33	SD-102-7-2	AHU-102-7-1	SEVENTH FLOOR	SD			14	8																					
34	SD-102-7-3	AHU-102-7-1	SEVENTH FLOOR	SD			16	46																					
35	SD-102-7-4	DVF-102-18-1	SEVENTH FLOOR	SD			14	14																					
36	SD-102-8-1	AHU-102-8-1	EIGHTH FLOOR	SD			18	54																					
37	SD-102-8-2	AHU-102-8-1	EIGHTH FLOOR	SD			14	8																					
38	SD-102-8-3	AHU-102-8-1	EIGHTH FLOOR	SD			16	46																					
39	SD-102-8-4	RF-102-8-1	EIGHTH FLOOR	SD			12	16																					
40	SD-102-8-5	DVF-102-18-1	EIGHTH FLOOR	SD			14	14																					
41	SD-102-9-1	AHU-102-9-1	NINTH FLOOR	SD			18	54																					
42	SD-102-9-2	AHU-102-9-1	NINTH FLOOR	SD			14	8																					
43	SD-102-9-3	AHU-102-9-1	NINTH FLOOR	SD			16	46																					
44	SD-102-9-4	DVF-102-18-1	NINTH FLOOR	SD			14	14																					
45	SD-102-10-1	AHU-102-10-1	TENTH FLOOR	SD			18	54																					
46	SD-102-10-2	AHU-102-10-1	TENTH FLOOR	SD			14	8																					
47	SD-102-10-3	AHU-102-10-1	TENTH FLOOR	SD			16	46																					
48	SD-102-10-4	RF-102-10-1	TENTH FLOOR	SD			12	16																					
49	SD-102-10-5	DVF-102-18-1	TENTH FLOOR	SD			14	14																					
50	SD-102-11-1	AHU-102-11-1	ELEVENTH FLOOR	SD			18	54																					
51	SD-102-11-2	AHU-102-11-1	ELEVENTH FLOOR	SD			14	8																					
52	SD-102-11-3	AHU-102-11-1	ELEVENTH FLOOR	SD			16	46																					
53	SD-102-11-4	DVF-102-18-1	ELEVENTH FLOOR	SD			14	14																					
54	SD-102-B-1	AHU-102-2-1	BASEMENT	SD			6	10																					
55	SD-102-B-2	AHU-102-2-1	BASEMENT	SD			8	28																					
56	SD-102-B-3	AHU-102-2-1	BASEMENT	SD			6	10																					
57	SD-102-B-4	GEF-102-12-1	BASEMENT	SD			6	10																					
58	SD-102-B-5	AHU-102-2-1	BASEMENT	SD			6	20																					
59	SD-102-B-6	AHU-102-2-1	BASEMENT	SD			6	14																					
60	SD-102-B-7	AHU-102-2-1	BASEMENT	SD			6	10																					
61	SD-102-B-8	AHU-102-2-1	BASEMENT	SD			8	10																					
62	SD-102-B-9	AHU-102-2-1	BASEMENT	SD			10	8																					
63	SD-102-B-10	AHU-102-2-1	BASEMENT	SD			8	8																					
64	SD-102-B-11	GEF-102-3-1	BASEMENT	SD			8	24																					
65	SD-102-B-12	GEF-102-3-1	BASEMENT	SD			8	24																					
66	SD-102-B-13	AHU-102-B-2	BASEMENT	SD			8	14																					
67	SD-102-B-14	AHU-102-B-2	BASEMENT	SD			8	12																					
68	SD-102-B-15	AHU-102-2-1	BASEMENT	SD			16	24																					

Sample for Format