



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. 44590**

**HVAC Work  
Replace Hot Water Heating System,  
Vehicle Bays  
DOT Region 8 Westchester County  
Route 100 RD2  
Katonah, NY 10536**

August 5, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**SPECIFICATION GROUP**

1. DOCUMENT 002217 SUPPLEMENTARY INSTRUCTIONS TO BIDDERS- CONDITION OF

AWARD:

- a. 002217-1 Delete the following "1. Boiler submittals as per 235218 Condensing Boiler"

2. DOCUMENT 011000 SUMMARY OF THE WORK:

- a. 011000-1 1.04 RESTRICTED WORK PERIOD insert the following:
  - b. D. Do not perform work on the hydronic portion of the heating system between October 15<sup>th</sup> and May 1st unless approved otherwise, in writing, by the director.
  - c. E. Perform work on the panel radiators in the North and East wings separately and only during specified times, with written permission from the director. DOT will vacate each wing for a period of four weeks during which contractor shall perform the work and provide construction

heat. Contractor shall provide temporary heat after four weeks until such time as the new system is fully operational.

**3. DOCUMENT 013300 SUBMITTALS**

- a. Due to a printer error, pages 0133000-10, 11, 12, 13 are blank. These four pages are sample forms BDC-42 Submittal Transmittal (which is printed in the Appendix), sample Submittal Comment form, Sample RFI form, and BDC-23 IB Form. All of these forms will be available for use on the Electronic Submittal Website after award. These sample forms can also be viewed now in the OGS Master Specification on the OGS Website at the following web address: [www.ogs.ny.gov](http://www.ogs.ny.gov) and clicking on Design & Construction, Master Specifications, Division 01-General Requirements, 013300 Submittals Electronic Version.

**4. DOCUMENT 015123 HEAT DURING CONSTRUCTION**

- a. Insert the following:

**1.05 CONSTRUCTION HEAT**

A. During each phase of work in the North and East wings, provide construction heat (as differentiated from temporary heat), of a nature as required and approved to accomplish the following:

- 1. Protect both existing systems and stored materials as well as materials and equipment being installed as part of the Contract from freezing.
- 2. Enable workers to accomplish their respective tasks in a satisfactory manner.

3. Maintain construction schedules.

B. Do not use electric heaters.

**END OF ADDENDUM**

Margaret F. Larkin  
Acting Executive Director