



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 3 TO PROJECT NO. 44590

**HVAC Work
Replace Hot Water Heating System,
Vehicle Bays
DOT Region 8 Westchester County
Route 100 RD2
Katonah, NY 10536**

August 8, 20014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CHANGES TO ADDENDUM NO. 1

Item No. 2, 011000 Summary of the Work, part (c), insert the following:

“Per the facility’s request, perform the work in the East wing first, followed by the work in the North Wing.”

Item No. 4, 1.05 Construction Heat, part (A), delete the text “North and East wings” and insert the text “East and North wings”.

CHANGES TO ADDENDUM NO. 2

Item No. 2, delete the words “....North Truck Bay and another 4 consecutive weeks for the East Truck Bay” and insert the words “....East Truck Bay and another 4 consecutive weeks for the North Truck Bay”.

Item No. 5, insert the following:

“The State is only obligated to pay for temporary heat under certain conditions including but not limited to the following. Example 1: The existing heating system fails prior to the beginning of the four consecutive week construction phase in either the East or North wing. Example 2: The state wishes to provide temporary electric heat in the office areas during scheduled 4 hour shutdowns of the propane supply. The contractor remains obligated to provide construction heat during each four week construction phase as outlined above in item 4. The contractor will be responsible for supplementary heat upon conclusion of either or both four week construction periods if the schedule is not met, until such time as the new heating system is operational in each wing, as outlined below in item 6.”

END OF ADDENDUM

Margaret F. Larkin
Acting Executive Director