



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. 44630-C**

**CONSTRUCTION WORK  
REHABILITATE WATER STORAGE TANK  
CHATEAUGAY CORRECTION FACILITY  
P.O. BOX 319  
ROUTE 11  
CHATEAUGAY, NEW YORK**

February 21, 2013

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.  
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**DRAWINGS**

1. Add to Drawing No. C-100:

**NOTES:**

**TEMPORARY WATER SYSTEM**

1. The contractor is responsible for bringing the existing hydro-pneumatic temporary water system online during the tank painting and shall coordinate with the Director's Representative to do so. Work shall include:
  - a. The contractor shall operate the valves on the water system as directed by the Director's Representative to isolate the water storage tank from the distribution system.
  - b. The contractor shall disconnect the pressure transducer in the water storage tank from the controls and connect the pressure transducer in the hydro-pneumatic tank.
  - c. The contractor shall connect the power that feeds the tank air charging system.
  - d. The contractor shall test water flow and pressure in the facility after startup of the temporary water system in the presence of the Director's Representative.
2. After the project has been complete the contractor shall return the water system to normal operation by performing the following:
  - a. The contractor shall disconnect the pressure transducer in the hydro-pneumatic tank from the well controls and re-connect the pressure transducer in the water storage tank.
  - b. The contractor shall disconnect power to the tank air charging system mounted on the hydro-pneumatic water tank.

- c. The contractor shall operate the existing valves on the water system as directed by the Director's Representative to provide flow of water from the treatment plant, through the hydro-pneumatic tank and into the water storage tank.
- d. The contractor shall monitor operation of the well pumps and chemical injection system until the water storage tank is completely filled and operational in the presence of the Director's Representative."

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design