



**DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242**

---

**ADDENDUM NO. 3 TO PROJECT NO. 44647**

**CONSTRUCTION WORK  
UPGRADE INPATIENT LOCKING SYSTEM  
PHASE II, BUILDING 39  
Central New York Psychiatric Center  
River Road, Marcy, NY**

October 19, 2015

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**DRAWINGS**

1. Drawing No. A-600, DOOR TYPES
  - a. Door Type NL: Change the note "TG" to read "Refer to General Door Note 8".
  - b. Door Type V: Change the note "TG" to read "Refer to General Door Note 8".

Drawing No. A-600, GENERAL DOOR, FRAME AND HARDWARE NOTES.

a. Add note 8 to read:

"Provide Type G glass at doors requiring a fire-resistance rating. Refer to the "Rating" column in the Door Schedule for each doors required fire-resistance rating. Provide Type S-1 glass at doors not listed as requiring a fire-resistance rating".

**END OF ADDENDUM**

Margaret F. Larkin  
Executive Director  
Design and Construction