



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 1 TO PROJECT NO. 44656

**CONSTRUCTION, HVAC, PLUMBING and ELECTRIC WORK
PROVIDE PRE-ENGINEERED METAL BUILDING
MAINTENANCE SUB-HEADQUARTERS
DOT REGION 4, WYOMING COUNTY
ROUTE 78, JAVA, NY 14082**

March 31, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATION GROUP:

CONSTRUCTION SPECIFICATION

1. 133419 PRE-ENGINEERED METAL BUILDING: Delete Article 2.06 in its entirety.

PLUMBING SPECIFICATION

2. 221323 ABOVE GROUND FUEL STORAGE TANKS AND FUEL SYSTEMS: Delete in their entirety ARTICLES 2.06 and 2.07.

DRAWINGS:

3. Drawing No. P-100 JAVA CENTER SITE PLAN & DIESEL TANK DETAILS:
 - a. DETAILS 2 AND 3: Change the title " 4000 GALLON DIESEL TANK " To read " 8' DIA. 4000 GALLON DIESEL TANK "
4. Drawing No. E-105 JAVA CENTER DETAILS:
 - a. DETAILS 1, 2 AND THE CONTROL / POWER WIRING DIAGRAMS FOR ABOVE GROUND FUEL STORAGE TANKS: Delete all references to electronic leak detection and fuel monitoring systems, sensors, probes, wiring, panels and conduits in their entirety.
5. Drawing No. E-104 JAVA CENTER DETAILS:
 - a. POWER ONE LINE DIAGRAM: In the note regarding automatic transfer switch replace all references to KSS/KSP with KSS-DCTA0225S or approved equal.

END OF ADDENDUM

Margaret F. Larkin
Acting Executive Director