




STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 3 TO PROJECT NO. 44664

**ELECTRICAL WORK
REPLACE ELECTRICAL SWITCHES
EMPIRE STATE PLAZA
ALBANY, NY**

November 26, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

ELECTRICAL WORK SPECIFICATIONS

1. Page 260573-1, Article 1.02 SCOPE: Add the following Paragraphs:
 - “C. The studies shall only include the overcurrent protective devices (OCPD) that are to be replaced and the main OCPD in each switchboard in which a feeded OCPD is to be replaced, with the exception of the Emergency O-P switchboard. The studies for the Emergency O-P switchboard shall only include the (1) feeder OCPD that is to be replaced the main OCPD (that is replaced) and the network protectors upstream of the switchboard.
 - D. Electronic versions of existing studies, including SKM files, from Utility to Switchboard level will be provided by Director’s Representative after the contract is awarded.”

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction