



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44666**

**CONSTRUCTION WORK  
REPLACE SECURITY WINDOWS  
BUILDINGS 7 AND 15  
ATTICA CORRECTIONAL FACILITY  
639 EXCHANGE STREET, P.O. BOX 149  
ATTICA, NY**

March 16, 2015

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**SPECIFICATIONS**

1. SECTION 085663 STEEL DETENTION WINDOWS, PART 2 PRODUCTS, 2.02 FABRICATION, PARAGRAPH K, TOOL RESISTANT STEEL.

**DELETE:** PARAGRAPH K referencing Type 1 Detention Windows ½” square tool resistant steel detention bars on both vertical and horizontal muntins.

**DRAWINGS**

2. Drawing No. A-502 - WINDOW DETAILS BUILDING NO. 7, SILL DETAILS #1, #4, AND #7.

**DELETE:** Delete the ½” square tool resistant steel bar located on the underside of the horizontal bulb tee muntin stem.

3. Drawing No. A-103, revised 03-04-15, -FIRST FLOOR PLAN AND ELEVATION BUILDING NO. 15.

**CHANGE:** 2 Window configurations marked as “W18” located on the north wall in Break Room # 106 **to** window configuration W17.

4. Drawing No. A-105 - FIRST FLOOR PLAN COURTYARDS BUILDING NO. 15

**CHANGE:** 2 Window configurations marked as “W18” located on the north wall in Break Room # 106 **to** window configuration W17.

5. Drawing No. A-503 - WINDOW TYPES BUILDING NO. 15, DETAIL #1 WINDOW TYPES.

**DELETE:** Window configuration W14a.

6. Drawing No. A-103 - FIRST FLOOR PLAN AND ELEVATION BUILDING NO. 15

**CHANGE:** Window configuration “W4.1” located in Toilet Room # 111 to window configuration W4.

7. Drawing No. A-501 - WINDOW TYPES AND DETAILS BUILDING NO. 7,  
DETAIL #1 WINDOW TYPES.

**ADD:** to the restoration drawing note at window configuration W7, the following:  
Contractor is to replace 3 SF of the total glass and 10% of the caning at each window panel.

8. Drawing No. A-503- WINDOW TYPES BUILDING NO. 15, DETAIL #1 WINDOW TYPES.

**ADD:** window configuration W4.2, window to be 2'-3 ½" wide x 5'-0 ¼" tall and should be configured similar to window configuration W4.1.

**END OF ADDENDUM**

Margaret F. Larkin  
Executive Director  
Design and Construction