



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44684

**HAZARDOUS MATERIALS WORK
ASBESTOS ABATEMENT
BUILDING NO. 9
FOURTH FLOOR
STATE OFFICE BUILDING CAMPUS
1220 WASHINGTON AVENUE
ALBANY, NY**

April 11, 2013

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. Page 011000-1, Paragraph 1.02.B.: Delete this Paragraph in its entirety, and replace with the following:
 - “B. Further sequencing will be required as the primary supply air ductwork must remain active throughout the work.
 1. Refer to the approved site specific variance included in the Appendix of the Project Manual, and H-series drawings for requirements.
 2. The return air and secondary supply air systems will be required to be shutdown to allow for disconnections to be completed at shafts 1, 2, & 3.
 3. Coordinate this shutdown with the Director’s Representative.
2. Page 011000-1, Paragraph 1.09.A.: Delete this Paragraph in its entirety, and replace with the following:
 - “A. Perform all the Work of this Contract between the hours of 6:00 pm and 6:00 am Monday thru Thursday, and on weekends between the hours of 6:00 pm Friday and 6:00 am on Monday, unless otherwise directed in writing by the Director’s Representative.

END OF ADDENDUM

James Dirolf, P.E.
Director of Design