



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44709

**CONSTRUCTION, PLUMBING WORK
REPLACE WATER MAIN, ANNEX
CLINTON CORRECTIONAL FACILITY
1074 ROUTE 374, DANNEMORA, CLINTON COUNTY, NY**

March 24, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATION GROUP, CONSTRUCTION & PLUMBING

1. Page 312316 – 2, Replace the existing subparagraph 1.06(A)(2) with the following:
 2. Limit peak particle velocity from blasts to a maximum of 2 inches per second at adjacent structures.

CONSTRUCTION WORK DRAWINGS

1. Drawing C-103: For the size reference on water line segment L, replace 8" DIP with 12" DIP.

END OF ADDENDUM

Margaret F. Larkin
Acting Executive Director