



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44718**

**CONSTRUCTION WORK  
REPLACE FIRE ESCAPES  
ADMINISTRATION BUILDING  
OTISVILLE CORRECTIONAL FACILITY  
57 SANATORIUM AVENUE  
OTISVILLE, NY**

January 28, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION DRAWINGS**

1. Drawing S-102, General Notes:
  - a. Add “(7) Replace (16) 11” x 3’-6” stair treads, (1) 5’-6½” x 3’-6” landing and (1) 7’-4½” x 4’-2½” landing on North stairs of Building 26 with galvanized wheels and heels style grating. Touchup all welds and damages from removals with cold galvanizing compound. Turn over removed treads and landings to the facility where directed.”

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design