



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 1 TO PROJECT NO. 44731**

**HVAC WORK  
REPLACE BOILERS  
QUEENSBORO CORRECTIONAL FACILITY  
47-04 VAN DAM STREET  
LONG ISLAND CITY, NY**

September 25, 2015

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**DRAWINGS**

1. Drawing No. M-001, GENERAL NOTES, Note 10 : Delete this Note in its entirety.
2. Drawing No. H-101, BOILER ROOM ABATEMENT PLAN:
  - a. NOTES, Note 1: Delete this Note in its entirety and replace with the following:
    - “1. THE EXISTING BREECHING INSULATION AND HANGAR PADS SHALL BE CONSIDERED PACM AND SHALL BE REMOVED AND DISPOSED IN ACCORDANCE WITH SPEC. SECTION 028213.”
  - b. ASBESTOS ABATEMENT PLAN – BOILER ROOM: Change note, “REMOVE AND DISPOSE OF ALL BOILER BREECHING INSULATION IN ITS ENTIRETY FROM BREECHING, BOILERS, AND CONNECTION TO CHIMNEY AS WELL AS BOILER(S) GASKETS AND HANGAR PADS. SEE NOTE 1.”, which points to breeching and boilers to read “REMOVE AND DISPOSE OF ALL BOILER BREECHING INSULATION IN ITS ENTIRETY FROM BREECHING AND BREECHING HANGER PADS. SEE NOTE 1.”

**END OF ADDENDUM**

Margaret F. Larkin  
Executive Director  
Design and Construction