

---

---

**ADDENDUM NO. 2 TO PROJECT NO. 44770**

**CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, ELECTRIC WORK  
REHABILITATE BATHROOMS  
HIGHLAND RESIDENTIAL CENTER  
629 NORTH CHODIKEE LAKE ROAD  
HIGHLAND, NEW YORK 12528**

January 28, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.  
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CONSTRUCTION WORK**

**DRAWINGS**

1. Addendum Drawings:
  - a. Drawing ADA-101 accompanies this Addendum and forms part of the Contract Documents.
  - b. Drawing ADA-102 accompanies this Addendum and forms part of the Contract Documents.
  - c. Drawing ADA-103 accompanies this Addendum and forms part of the Contract Documents.
  
2. Drawing A-101:
  - a. Detail 2: Replace this detail with Addendum Drawings ADA-102 and ADA-103.
  - b. Detail 3: Replace this detail with Addendum Drawing ADA-101.
  
3. Drawing A-106:
  - a. Detail 1, Corridor 4017:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
    - 2) At note reading “INFILL OPENING AT DRINKING FOUNTAIN REMOVAL” add the following:  
“CUT AND PATCH WALL AS REQUIRED FOR INSTALLATION OF VALVE CABINET BY PLUMBING CONTRACTOR-COORDINATE WITH P CONTRACT”.

- b. Detail 1, Room 4019:
    - 1) Add the following note:  
“CUT AND PATCH CHASE WALL TO ALLOW INSTALLATION OF WATERCLOSET AND CARRIER BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”
  - c. Detail 2, Corridor 4118:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
  - d. Detail 2, Corridor 4018:
    - 1) At note reading “INFILL OPENING AT DRINKING FOUNTAIN REMOVAL” add the following:  
“CUT AND PATCH WALL AS REQUIRED FOR INSTALLATION OF VALVE CABINET BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”.
  - e. Detail 2, Room 4130:
    - 1) Add the following note:  
“CUT AND PATCH CHASE WALL TO ALLOW INSTALLATION OF WATERCLOSET AND CARRIER BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”.
  - f. Detail 7, adjacent to Room 4105 in Room 4106:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
4. Drawing A-107:
- a. Detail 1, Corridor 4217:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
    - 2) At note reading “INFILL OPENING AT DRINKING FOUNTAIN REMOVAL” add the following:  
“CUT AND PATCH WALL AS REQUIRED FOR INSTALLATION OF VALVE CABINET BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”.
  - b. Detail 1, Room 4230:
    - 1) Add the following note:  
“CUT AND PATCH CHASE WALL TO ALLOW INSTALLATION OF WATERCLOSET AND CARRIER BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”

- c. Detail 2, Corridor 4321:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
    - 2) At note reading “INFILL OPENING AT DRINKING FOUNTAIN REMOVAL” add the following:  
“CUT AND PATCH WALL AS REQUIRED FOR INSTALLATION OF VALVE CABINET BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”.
  - d. Detail 2, Room 4318:
    - 1) Add the following note:  
“CUT AND PATCH CHASE WALL TO ALLOW INSTALLATION OF WATERCLOSET AND CARRIER BY PLUMBING CONTRACTOR - COORDINATE WITH P CONTRACT”.
  - e. Detail 7, adjacent to Room 4305 in Room 4301:
    - 1) Add the following note:  
“CUT AND REMOVE EXISTING FLOOR SLAB AND TILE TO ALLOW INSTALLATION OF UNDERSLAB SANITARY LINES BY PLUMBING CONTRACT. PATCH SLAB AND FLOOR TO MATCH EXISTING UPON COMPLETION. TIE PATCH INTO EXISTING PER DETAIL 8/A-107 SIMILAR. PATCH FLOOR TILE TO MATCH EXISTING”.
5. Drawing A-109:
  - a. Detail 2:
    - 1) Add the following note:  
“ROOM NUMBERS ON THIS DETAIL ARE INCORRECT – SEE 2/A-107 FOR ROOM NUMBERS”.

**HVAC WORK**


**SPECIFICATIONS GROUP**

**DIVISION 23 – HEATING, VENTILATING AND AIR CONDITIONING**

- 6. SECTION 238236 FINNED TUBE RADIATION:
  - a. Page 238236-2, Paragraph Article 2.01 A: Change “18 USS gage sheet steel” to read “14 USS gage sheet steel”.
  - b. Page 238236-2, Paragraph Article 2.01 C: Delete this paragraph in its entirety.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design



**BUILDING 29 REMOVALS PLAN**

**3**

ADDENDUM DRAWING



NYS OFFICE OF GENERAL SERVICES

*Serving New York*

**CONTRACT:** CONSTRUCTION  
**PROJ. NO:** 44770-C  
**DATE:** 1/28/14  
**DRAWN:** JCR  
**APPROVED:** JCR

**SHEET TITLE:**

REMOVALS PLAN  
 BUILDING 29


**PROJECT:**

REHABILITATE BATHROOMS  
 HIGHLAND RESIDENTIAL CENTER

WARNING: THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.

**DWG NO:**

ADA-101



NOTE: SEE TOILET ROOM 2901 FOR FLOOR PITCH INFO  
 SEE TOILET ROOM 2902 FOR GENERAL NOTES  
 TYPICAL ALL TOILET SHOWER ROOMS THIS PLAN

## 2 BUILDING 29 LARGE SCALE PLAN

ADDENDUM DRAWING



**CONTRACT:** CONSTRUCTION  
**PROJ. NO:** 44770-C  
**DATE:** 1/28/14  
**DRAWN:** JCR  
**APPROVED:** JCR

**SHEET TITLE:**

LARGE SCALE PLAN  
 BUILDING 29


**PROJECT:**

REHABILITATE BATHROOMS  
 HIGHLAND RESIDENTIAL CENTER

WARNING: THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS 'A' MISDEMEANOR.

**DWG NO:**

ADA-102



**BUILDING 29 LARGE SCALE PLAN**

**2**

ADDENDUM DRAWING



NYS OFFICE OF GENERAL SERVICES

*Serving New York*

**CONTRACT:** CONSTRUCTION

**PROJ. NO:** 44770-C

**DATE:** 1/28/14

**DRAWN:** JCR

**APPROVED:** JCR

**SHEET TITLE:**

LARGE SCALE PLAN  
BUILDING 29

**PROJECT:**

REHABILITATE BATHROOMS  
HIGHLAND RESIDENTIAL CENTER

WARNING: THE ALTERATION OF THIS MATERIAL IN ANY WAY, UNLESS DONE UNDER THE DIRECTION OF A COMPARABLE PROFESSIONAL, I.E. ARCHITECT FOR AN ARCHITECT, ENGINEER FOR AN ENGINEER OR LANDSCAPE ARCHITECT FOR A LANDSCAPE ARCHITECT, IS A VIOLATION OF THE NEW YORK STATE EDUCATION LAW AND/OR REGULATIONS AND IS A CLASS "A" MISDEMEANOR.

**DWG NO:**

ADA-103