



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 3 TO PROJECT NO. 44791-C**

**CONSTRUCTION WORK  
REHABILITATE WINGS 1-4,  
ASBESTOS ABATEMENT  
TILE FLOORS  
BROOKWOOD SECURE CENTER  
PO BOX 419, CR 29  
CLAVERACK, NY 12513**

January 31, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**CHANGES TO ADDENDUM NO. 1**

1. Delete Item No. 7 in its entirety.

**SPECIFICATION GROUP**

2. Page 096500-4, Paragraph 3.04C.: Delete this paragraph in its entirety.

**DRAWINGS**

3. Drawing No. A-101:
  - a. KEYED NOTES, Change Note 1 to read:  
“Note 1 Containment area access. Provide temporary barrier with lockable door for the duration of construction in each work area.”
  - b. ASBESTOS ABATEMENT NOTES, AR1: Change “use of solvents and/or chemicals will not be permitted.” to “use of no odor/ low VOC solvents/ removers will be permitted with product approval from the OGS Director’s Representative (Division of Design).”
  - c. FIRST FLOOR PLAN 1/A-101: Change “3/32” to “1/8”.
  - d. FIRST FLOOR PLAN 1/A-101: Change all notes that read “Containment area access” to “Permissible Negative Air Exhaust Location.”
  - e. SECOND FLOOR PLAN 2/A-101: Change all notes that read “Containment area access” to “Permissible Negative Air Exhaust Location.”

4. Drawing No. A-102:
  - f. LEGEND, shaded symbol description, Add the following:

“At all areas of epoxy floor finish, paint type HPE, provide epoxy paint wall base, paint type HPE, for entire perimeter of room per General Note #1 this drawing.”
  - g. LEGEND, epoxy shaded symbol description: Change “4,699 SF” to “4,980 SF (total square footage of flooring and base)”.
  - h. LEGEND, carpet hatch symbol description: Add the following:

“Provide wood wall base per Detail 7/ A-102 for entire perimeter of carpet area indicated.”
  - i. LEGEND, carpet hatch symbol description: Change “1,828 SF” to “1,564 SF”.
  - j. LEGEND, VCT hatch symbol description: Add the following:

“Provide wood wall base per Detail 7/ A-102 for entire perimeter of VCT area indicated.”
  - k. LEGEND, VCT hatch symbol description: Change “1,717 SF” to “2,044 SF”.
  - l. FIRST FLOOR PLAN 1/A-102: Change “3/32” to “1/8”.
  - m. FIRST FLOOR PLAN 1/A-102: Change carpet hatch symbol in Foyer 1-80 and Foyer 1-125 to VCT hatch symbol.
  - n. FIRST FLOOR PLAN 1/A-102: Change carpet hatch symbol in Foyer 1-129 and Foyer 2-1 to VCT hatch symbol.

**END OF ADDENDUM**

James Dirolf, P.E.  
Director of Design

EJB/DWM