



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 3 TO PROJECT NO. 44836-E

**UPGRADE ELECTRICAL SYSTEM
DOT REGION 4, MONROE COUNTY
VARIOUS LOCATIONS**

September 30, 2014

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. Section 262726 - Wiring Devices:

A. Add the following new Article 2.05:

"2.05 WEATHERPROOF CORD REEL

- A. Positive stop action at any length, ratchet lock and automatic rewind spring. Powder coated corrosion resistant cast aluminum die cast construction in a weather-and dust-tight NEMA 4 housing. Provide water and oil resistant 12/3 SJEO cable (Minimum 30 feet) terminating in a weatherproof outlet box with one (1) GFCI 5-20R duplex receptacle.
- B. Acceptable Manufacturers:
1. Hubbell
 2. Appleton
 3. Woodhead"

END OF ADDENDUM

Margaret F. Larkin
Executive Director