



**DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242**

**ADDENDUM NO. 1 TO PROJECT NO. 44839
CONSTRUCTION WORK, HVAC WORK, PLUMBING WORK, AND ELECTRICAL WORK
REHABILITATE BUS LOOP AND CONCRETE ROADWAYS
EMPIRE STATE PLAZA
ALBANY, NY**

August 10, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

CONSTRUCTION WORK SPECIFICATIONS

1. Page 321373-2, Paragraph 2.01 A: Delete this Paragraph in its entirety and replace with the following:
 - “A. Type 1B Sealant:
 1. For Horizontal Joints: One-part, self-leveling silicone or polyurethane sealant for traffic bearing construction; Bostik Chem-Calk 955-SL, Tremco Vulkem 45, Pecora Urexpan NR-201, Pecora 300-SL, Pecora 310-SL, Sika Sikaflex-1CSL, Dow Corning CCS.
 - a. Exception: Use only silicone based sealants for the Rams Horn.
 2. For Vertical Joints: One-part, non-sag silicone or polyurethane sealant; Tremco Vulkem 116, Pecora Dynatrol I, Sika Sikaflex Textured Sealant, Dow Corning CCS or CWS, Pecora 301-NS, Pecora 311-NS.
 - a. Exception: Use only silicone based sealants for the Rams Horn.”

CONSTRUCTION WORK DRAWINGS

2. Drawing No. S-309, DETAIL 7/S-309:
 - a. Change “ 2 inch” strip width of liquid membrane and reinforcing fabric to read “4 inch”.
3. Drawing No. A-601, DOOR SCHEDULE AND DETAILS:
 - a. Detail 3/A-601; Change bottom rail height at doors from 6 inch to 10 inch.
 - b. Detail 6/A-601: Change bottom rail height at doors from 6 inch to 10 inch.

HVAC WORK DRAWINGS

4. Drawing No. M-100, Detail 2/M-100: Change the scale to read $\frac{1}{2}''=1'-0''$.
5. Drawing No. M-104, Detail 2/M-104: Change the scale to read $\frac{1}{2}''=1'-0''$

PLUMBING WORK DRAWINGS

6. Drawing No. P-102, Details 1/P-102, 2/P-102, 3/P-102, 4/P-102, 5/P-102 and 6/P-102: Change the scale on these details to read $\frac{1}{2}''=1'-0''$.
7. Drawing No. P-105, Details 1/P-105, 2/P-105, 3/P-105, 4/P-105, 5/P-105 and 6/P-105: Change the scale on these details to read $\frac{1}{2}''=1'-0''$.

ELECTRICAL WORK

8. No addenda at this time.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction