



ADDENDUM NO. 2 TO PROJECT NO. 44910

**ELECTRICAL WORK
SEPARATION OF ELECTRICAL SYSTEMS
DOT REGION 10, SUFFOLK COUNTY
371 CARLETON AVENUE
CENTRAL ISLIP, NY**

July 9, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

SPECIFICATIONS

1. PAGE NO. 260501-5, ARTICLE 2.02 JUNCTION, SPLICE, AND PULL BOXES: ADD THE FOLLOWING PARAGRAPH:
 - “D. Polymere Concrete Type: Highline Products and Hubbell Quazite.
 1. Meets ANSI Tier 5 applications.
 2. Made from non-metallic, non-conductive, and non-flammable material.
 3. Impact and corrosion resistant.
 4. Skid resistant cover.
 5. Non-conductive.
 6. Corrosion resistant hardware for securing cover.
 7. Provide logo “ELECTRIC” application and load rating logo on cover.”

DRAWINGS

1. DRAWING E-600, MAINTENANCE HEADQUARTERS BLDG. NO. 2, PANELBOARD SCHEDULE, DESIGNATION MDP:
 - a. Un-check box for ‘MAIN LUG ONLY’
 - b. Un-check box for ‘MICROPROCESSOR BASED MULTIFUNCTION POWER AND ENERGY METER’

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction