



**DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242**

ADDENDUM NO. 2 TO PROJECT NO. 44984-E

**ELECTRICAL WORK
UPGRADE ELECTRICAL SYSTEM
EDGEcombe CORRECTIONAL FACILITY
611 EDGEcombe AVE
NEW YORK, NY 10032**

March 17, 2017

<p>NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.</p>
--

CHANGES TO ADDENDUM NO. 1

1. Item No. 1b: Replace the whole paragraph with:
SEQUENCE OF WORK, add the following to note 2:
“Panelboard replacement interruptions that extend beyond one hour shall be limited to one panel only. Temporary connection shall be made to maintain other panels on the feeder energized after the one hour duration.”
2. Item No. 1c2: Change “PP-43” to “PP-4”.

DRAWINGS

1. Drawing No. E-111:
 - a. At bottom of Laundry Room Panel schedule, add:
“*NOTES (For This Drawing only):
Laundry Room Panel is existing to remain and the schedule is for information only.”
2. Drawing No. E-117:
 - a. Under the Schedule for Cable and Raceway, add:
“NOTES (For This Drawing only):
Provide 200 feet of 4 #2 AWG and 1 #8 EGC in 1 ½” rigid galvanized steel conduit from existing panel DB-1 to each of panels PP-2, PP-4 and PP-H.”

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction