



STATE OF NEW YORK
OFFICE OF GENERAL SERVICES
DESIGN AND CONSTRUCTION GROUP
THE GOVERNOR NELSON A. ROCKEFELLER
EMPIRE STATE PLAZA
ALBANY, NY 12242



ADDENDUM NO. 2 TO PROJECT NO. 44988

**CONSTRUCTION WORK
REPLACE ROOFS, ANNEX BUILDING 1
TABERG RESIDENTIAL CENTER FOR GIRLS
10011 TABERG-FLORENCE ROAD
RR NO.1, BOX 139
TABERG, NY 13471**

March 4, 2015

NOTE: This Addendum forms a part of the Contract Documents. Insert it in the Project Manual. Acknowledge receipt of this Addendum in the space provided on the Bid Form.

BIDDING REQUIREMENTS

1. DOCUMENT 000101 TITLE PAGE (COVER): Pre-Bid Site Visit - Change "FEBRUARY 27, 2015" to "MARCH 5, 2015".
2. DOCUMENT 001114 ADVERTISEMENT FOR BIDS: Pre-Bid Site Visit - Change "10:00 a.m. on February 27, 2015" to "2:00 p.m. on March 5, 2015".

The only time prospective bidders will be allowed to visit the job site to take field measurements and examine existing conditions of the project area will be at 10:00 a.m. on March 5, 2015 at Taberg Residential Center for Girls, Conference Room, 10011 Taberg Florence Road, Taberg, NY. Prospective bidders are urged to visit the site at this time. Prospective bidders or their representatives attending the pre-bid site visit will not be admitted on facility grounds without proper photo identification. Note that parking restrictions and security provisions will apply and all vehicles will be subject to search.

For assistance pertaining to the site visit only, please phone Tracy Gualtieri (315) 339-6820 Ext. 221.

DRAWINGS

3. Drawing No. S-102:
 - a. TRUSS REPLACEMENT PLAN 1/S-102: Change note to Read:

"EXISTING ROOF TRUSSES TO REMAIN IN PLACE, INCLUDING ALL EXISTING CEILING FINISHES AND SUPPORTED UTILITIES AND DEVICES. REMOVE EXISTING ROOF ASSEMBLY, INCLUDING ROOF DECK, TO EXPOSE EXISTING TRUSSES. TEMPORARILY REMOVE ALL BRIDGING AND APPURTENANCES PERPENDICULAR TO TRUSS SPAN. INSTALL TRUSSES PER SECTION 3/ S-102, ADJACENT AND FREE OF EXISTING FRAMING AND INSTALL BRIDGING. TRUSSES SHALL BE SET 1" HIGHER THAN EXISTING TO ACCOMMODATE FOR DEFLECTION."

- b. TRUSS REPLACEMENT LOAD DIAGRAM 3/S-102: Delete graphic for continuous angles and associated callout in their entirety.
- c. WALL STUD BOTTOM CHORD CONNECTION 4/S-102: Delete detail in its entirety.

END OF ADDENDUM

Margaret F. Larkin
Executive Director
Design and Construction