



STATE OF NEW YORK  
OFFICE OF GENERAL SERVICES  
DESIGN AND CONSTRUCTION GROUP  
THE GOVERNOR NELSON A. ROCKEFELLER  
EMPIRE STATE PLAZA  
ALBANY, NY 12242



---

---

**ADDENDUM NO. 2 TO PROJECT NO. 45060**  
**REPAIR / REPLACE ROOF**  
**DOT Region 1, Waterford**  
**182 Davis Avenue**  
**Waterford, NY**

August 20, 2014

**NOTE:** This Addendum forms a part of the Contract Documents. Insert it in the Project Manual.  
Acknowledge receipt of this Addendum in the space provided on the Bid Form.

**SPECIFICATIONS**

1. Page 076000-2, Article 2.03, C, Add the following Paragraph:

“5. Aluminum Thickness: 0.063.”

**DRAWINGS**

2. Drawing No. H-101:
  - a. Asbestos Abatement Legend: Change “Existing Ballasted EPDM Roofing System” to “Existing Gravel-Surfaced Built-Up Roofing System”
3. Drawing No. A-101:
  - a. Removal Key Notes, Change Note 1 to Read:

“1. Removal of Existing Gravel-Surfaced Built-Up Roofing System by Asbestos Contractor. Refer to H-101 and Specifications 003126, 028213 and 028304.”

**END OF ADDENDUM**

Margaret F. Larkin  
Acting Executive Director